

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001


No: F 6/DFS/MS/2011/ *School/1881*

Dated:- *24/05/12*

FIRE SAFETY CERTIFICATE

Certified that the *Kendriya Vidyalaya Sector-25 at old bus stop of K4 Sec-8 Rohini, Delhi* comprised of *Ground floor (Temp. kutments)* owned/occupied by *Kendriya Vidyalaya Sec-25 Rohini Delhi* have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of Fire Service on *21.10.11* in the presence of *Smt. V. S. Sharma* and that the building/premises is fit for occupancy as *School (Education)* building with effect from *21.10.11* for a period of *Three year* in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on..... at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *Principal*
Kendriya Vidyalaya
Sector-25 at old bus stop of Kendriya Vidyalaya
Sector-8, Rohini, Delhi.
- 2.....
-
-

Note:-Guidelines overleaf may also be taken care of.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Kendriya Vidyalaya (Sec-25) at Sec-8, Rohini, Delhi.
2. Type of Occupancy : Edu Bldg. (Temp hutment)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. No. Dated:
5. Fire Safety directives letter No :
6. Date of inspection : 31.10.11
7. Name of the Inspecting Officers : Vipin Kantal.
8. Name and designation of officers from the building side : Smt. Veena.
9. Year of Construction : 2006
10. Applicant's letter No. : 190350/1/2011/E.O(M)/K.VS/D.S/3405-06 M-28-9/11.

NW - 2011-002072

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Approachable to Fire units.	Approachable 4.5 mtr 3 mtr	M/R " "
2	Number, Width, Type & Arrangement of Exits	<i>located on G.F only.</i>		
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 		N/A	
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1 mtr for each class room 705 students	single door of all class rooms	M/R except three class rooms having more than 45 students.

3	Compartmentation.							
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 							
4	Smoke Management System.							
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour						
		12 a/c per hour						
5	Fire Extinguishers							
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 							
		ISI marked						
							5 NO. 5 kg each ABC type	MIR
6	First-Aid Hose Reels.							
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 							
		30 m						
		5 mm						
7	Automatic fire detection and alarming system.							
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 							
8	MOEFA							
9	Public Address System.							
10	Automatic Sprinkler System.							
	<ul style="list-style-type: none"> • Basement 							

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	/		
11	Internal Hydrants	N.R		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	/		
12	Yard Hydrants.	N.R		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	/		
13	Pumping Arrangements.	N.A		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	/		
14	Captive Water Storage for fire fighting.	N.A		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	/		

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.		N.R	
16	Provision of Lifts.		NO lift	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		N.R	
18	Refuge Area.		N.R	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		N.R	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	NO special risk	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers...2(h.).....

5

Signature of the Inspecting Officer

Veerat
31/10/11
Signature of the Inspecting Officer

Name

Name *Vipin Kantal.*

Designation

Designation *DO, NW*