

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2011/ FW/2004

Dated:- 31/05/12

FIRE SAFETY CERTIFICATE

Certified that the M/S Supra fire works at Shop No. S-2/15 E-Block, DDA Market, Prashant Vihar Delhi comprised of Ground floor owned/occupied by M/S Gupta Fire works Prop. Sh. Rajesh Gupta complied with the Guide lines issued by Delhi Police under Delhi Police Act and verified by the officer concerned of Fire Service on 21-4-12 in the presence of Mr. Rajesh and that the building/premises is fit for occupancy Explosive Group J Hazards building with effect from 31/05/12 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/05/12 at New Delhi.


31/5
Chief Fire Officer

Delhi Fire Service

o/c

Copy to:-

1. The Adll. Commissioner of Police (Lic)
1st Floor P.S. Defence Colony
New Delhi

2. Sh. Rajesh Gupta Prop. R.S. Gupta
H.No. 4940/1, Punjabi Basti,
Shree Kothi, Sharda Gas Delhi 110007.

Note:- Guidelines overleaf may also be taken care of.

Received For Date
31-5-2012

RAJESH GUPTA
921246133

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

- 1. Name & address of the building Fireworks, shop No. S-2/15, E block, Prasant vihar, -Delhi-85
- 2. Type of Occupancy Storage (Explosive)
- 3. Type of Case : New Case/ Renewal
- 4. Details of previous NOC : Letter No. Nil Dated: —
- 5. Fire Safety directives letter No : NBC
- 6. Date of inspection 05-1-2012
- 7. Name of the Inspecting Officers : ADO - SHYAM LAL
- 8. Name and designation of officers from the building side : Sh. Vimal Goyal
- 9. Year of Construction Not known.
- 10. Applicant's letter No. (PF W/19/2011/61870-73/ Addl. CP (LIC)/Exp. dt. 16/11/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>19 mts.</u>	<u>02-85 mts.</u>	<u>NMR</u>
	• Gate width	<u>NA</u>	<u>Nil</u>	<u>Nil</u>
	• Width of internal road	<u>NA</u>	<u>Nil</u>	<u>Nil</u>
2	Number, Width, Type & Arrangement of Exits		<u>N.A.</u>	
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>2 m</u>	<u>3 mts,</u>	<u>MR</u>

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				NR
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			NR
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	4 ABC & W.CO2 ISI marked	4 ABC = 2 W.CO2 = 2 yes	M/R - - - - - -	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm			NR
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				NR
8	MOEFA				NR
9	Public Address System.				NR
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 				NR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			NR
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			NR
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			NR
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			NR
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			NIR
16	Provision of Lifts.			N/A
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			N/A
18	Refuge Area.			N/A
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			N/A
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			N/C

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers. 01.....

5

Signature of the Inspecting Officer

Shyam Lal
05/11/2012
Signature of the Inspecting Officer

Name

Name SHYAM LAL

Designation

Designation Assitt. Dirn. Officer

D.O. (NW)

The inspection format sent by Addl CP (HIC) under explosive Act is to be filled up.
The inspection report attained for further action

ADORN

U
9/11/12

Performa enclosed sir.

D.O. (NW)

Shyam Lal
ADORN
16/11/2012