

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/ School/2012/2028

Dated: 04/06/12

FIRE SAFETY CERTIFICATE

Certified that **Oxford Public School, Opp. Block No-4, Nehru Nagar, New Delhi**, comprised of basement (83 Sq Mtrs), ground plus three upper floors **Owned/Occupied by Oxford Public School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 23/05/2012 in the presence of Mr./Miss/Mrs. Gopal Sharma, Manager of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 04/06/12 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 04/06/12----- at New Delhi by


Chief Fire Officer
Delhi Fire Service

04/06/12

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Manager, Oxford Public School, Opp. Block No-4, Nehru Nagar, New Delhi-65

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : OXFORD PUBLIC SCHOOL
 : OPP- Block No: 4, NEHRU NAGAR, UD-65
 : _____
2. Type of Occupancy : EDUCATIONAL
3. Type of Case : NEW
4. Details of previous NOC : Nil Dt. _____
5. Fire Safety Directives letter No : Nil
6. Date of Inspection : 23/5/2012
7. Name of the Inspecting Officer : Rajan Wadehra, ADO/MPd.
8. Name and designation of the Officers from the building side : _____
9. Year of Construction : _____ Basement, Ground plus three upper floor
10. Applicant's letter No. : OPS/NN/2012/DD/54 (Basement = 83 Sq M²)

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 M ²	12 M ² ✓	M/R
	• Gate width	5 M ²	5 M ² ✓	M/R
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase			
	➤ Upper floors	2	2 ✓	M/R
	➤ Basement	NA	NA ✓	NA
	• Width of Staircase			
	➤ Upper floors	1.5 M ²	1.5 M ² ✓	M/R
	➤ Basement	NA	NA ✓	NA
	• Protection of Exits		NA	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	1	1 ✓	M/R
	• Width of Corridor	NA	NA	NA
	• Door Size	NA	NA	NA

Does not fall in the purview of DPSCs

3	Compartmentation	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System	NA		
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour		
		12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	One/300 m ²	10 NOS	M/R
			ABC, CO ₂	M/R
		ISI mark	YES	M/R
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	One/Per Floor	Provided	M/R
		30 m	30 m,	M/R
		5mm	5mm	M/R
7	Automatic Fire Detection and Alarming System	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 			
8	MOEFA	NA		
9	Public Address System	NA		
10	Automatic Sprinkler System	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrant			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	100 mm	150 mm	M/R
		One	Provided	M/R
		One	Provided	M/R
12	Yard Hydrant	NA		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			

13	Pumping Arrangements			
	Ground Level		NA	
	➤ Number of main pump			
	➤ Discharge of main pump			
	➤ Head of main pump			
	➤ Jockey pump out put			
	➤ Jockey pump Head			
	➤ Standby pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	M/R
	➤ Head of the pump	20 Mts	20 Mts	M/R
	➤ Power Supply	80 kVA	Provided	M/R
	➤ Auto starting /Manual stopping	Reqd.	Provided	M/R
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead tank capacity	15,000 Lts	15,000 Lts	M/R
15	Exit Signage	Required	Provided	M/R
16	Provision of Lifts		NA	
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply	80 kVA	Provided	M/R
18	Refuge Area		NA	
	• Total Area			
	• Location			
19	Fire Control Room		NA	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			


20	Special Fire Protection System for Protection of special risk, if any	N/A	N/A	N/A
----	---	-----	-----	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number~~.....

DO (South)


24/5/12


Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER