

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2012/2059

Dated: 06/06/2012

**FIRE SAFETY CERTIFICATE**


Certified that the **D-Mall** (Mera Baba Reality Pvt Ltd), Plot no. A-1, Netaji Subhash Place, Pitampura, New Delhi., comprised of three basement & twelve upper floors, was granted NOC by this department vide letter No. **F6/DFS/MS/2009/1197** dated **01/05/09**. The premises was re-inspected by the officers concerned of this department on **28/05/2012** in the presence of **Sh. Harish Rai General Manager** of the Mall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -F (Mercantile)** occupancy with effect from 06/06/12 for a period of three years subject to conditions printed overleaf.

Issued on.....06/06/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

Copy to:  
Sh. Harish Rai General Manager  
**D-Mall** (Mera Baba Reality Pvt Ltd),  
Plot no. A-1, Netaji Subhash Place, Pitampura, New Delhi



Note :- For general fire safety directives please over leaf.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

May Kindly peruse letter no. nil dated 09-05-2012 received from Sh. Harish Rai General Manager (D- Mall) regarding issue of NOC in favor of their D-Mall (Mera Baba Reality Pvt Ltd), Plot no. A-1, Netaji Subhash Place, Pitampura, New Delhi. Accordingly premises was inspected & observed that the building comprised of three basement & twelve upper floors. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **D-Mall** (Mera Baba Reality Pvt Ltd), Plot no. A-1, Netaji Subhash Place, Pitampura, New Delhi
2. Type of Occupancy : Class -F (Mercantile)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/1197 dated 01/05/09
5. Fire Safety directives letter No. : F6/MS/DFS/BP/2005/3071792 dated 30/08/05
6. Date of inspection : 28.05.2012
7. Name of the Inspecting Officers : A.D.O. Rajmal Khokhar & D.O. Sunil Chawdhary
8. Name and designation of officers  
From the building side : Sh. Harish Rai General Manager
9. Year of Construction :
10. Applicant's letter No. : nil dated 29-12-2011

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtrs	30 mtr	M/R
	• Gate width	6 mtr	6 mtr	M/R
	• Width of internal road	Required	provided	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	4	Provided	M.R.
	• Upper Floors	4	Provided	M.R.
	• Basement	1 ramp & 5 stairs	Provided	M.R.



b. Width of staircases				
	• Upper Floors	1.5 mtr & 1.25 mtrs	Provided	M.R.
	• Basement	1.5 mtr	Provided	M.R.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	4	provided	M.R.
	e. Width of Corridor	2	2.5	M.R.
f. Door size	1.5 mtrs	Provided	M.R.	
3.	<b>Compartmentation.</b>			
• Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers	Required	Provided	M.R.	
	Required	Provided	M.R.	
	1 hrs	Provided	M.R.	
	N.R.	N.A.	M.R.	
	Required	Provided	M.R.	
4.	<b>Smoke Management System.</b>			
• Basements • Upper floors	Required	Provided	M.R.	
	Required	Provided	M.R.	
5.	<b>Fire Extinguishers</b>			
• Total numbers • Types	55	provided	M.R.	
	ABC & CO <sub>2</sub>	provided	M.R.	

	• IS marking	required	provided	M.R ✓
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	• Total numbers on each floor	four	three	M.R ✓
	• Length of hose reel hose	30 m	required	M.R ✓
	• Nozzle diameter	5 mm	provided	M.R ✓
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	M.R ✓
	• Location of Main Panel	Ground floor	Provided	M.R ✓
	• Location of Repeater Panel	Ground floor	Provided	M.R ✓
	• Alternate source of power	Required	Provided	M.R ✓
	• Hooter's Location	All over building	Provided	M.R ✓
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R ✓
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R ✓
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided	M.R ✓
	• Upper Floor	Required	Provided	M.R ✓
	• Sprinkler above false ceiling	Required	Provided	M.R ✓
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	Provided	M.R ✓
	• Number of hydrants per floor	4	4	M.R. ✓


	• Hose Box	4	4	M.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	4	4	M.R.
	• Hose Box	4	4	M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	4500 LPM	Provided	M.R.
	➤ Head of Main pump	65 mtr	Provided	M.R.
	➤ Number of main pumps	2	Provided	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	65 mtr	Provided	M.R.
	➤ Standby pump out put	4500 LPM	Provided	M.R.
	➤ Standby pump Head	65 mtr	Provided	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	65 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.



<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	2,50,000 ltrs	provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	Required 50,000 ltrs	Provided	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	Required	Provided	M.R.
	• Pressurization of Lift lobby	Required	Provided	M.R.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R.
	• Lift Signage	Required	Provided	M.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R.
<b>18.</b>	<b>Refuge Area</b>	Required	Provided	M.R.
	➤ Total Area	Required	Provided at 4,8 & 9 <sup>th</sup> floor	M.R.
	➤ Location	4,8 & 9 <sup>th</sup> floor	Provided	M.R.
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	Required	Provided	M.R.
	➤ Flow Switch Panel	Required	Provided	M.R.

	➤ PA system Panel	Required	Provided	M.R. ✓
	➤ Batter backup	Required	Provided	M.R. ✓
	➤ Building Floor plans	Required	Provided	M.R. ✓
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name

RAJ MAL KHOKHAR

Name

Designation

A. D. O

Designation

20 (M. 14)

