

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DGS/MS/FW/2012/2057

Dated 06/06/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Parasnath & Company Proprietor Shri Sunil Jain and Smt. Anju Jain at ground floor Shop No. A-16, 100 Ft. Road, West Jyoti Nagar, Shahdara, Delhi, comprised of ground plus two upper floor owned/occupied by M/s Parasnath & Company Proprietor, have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of Fire Service on dated 18.05.12 in the presence of Mr. Sunil Jain and that the building is fit for occupancy class Fireworks storage with effect from 06/06/12 for a period of three years, subject to conditions printed overleaf.

Issued on 06/06/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

To,
The Additional Commissioner of police (Licensing),
1st Floor, P.S. Defence colony,
New Delhi.

Copy to:-

Shri Sunil Jain and Smt. Anju Jain (Proprietor)
M/s Parasnath & Company
Shop No. A-16, 100 Ft. Road,
West Jyoti Nagar, Shahdara.

gc
FSD
9/6/12

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Parasnath & Company Proprietor Shri Sunil Jain and Smt. Anju Jain at Shop No. A-16, 100 Ft. Road, West Jyoti Nagar, Shahdara, Delhi
2. Type of Occupancy : Storage Fireworks
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- _____ Dated _____
5. Fire Safety direction letter No : Delhi Police Act
6. Date of Inspection : 18.05.12
7. Name of the Inspecting Officers : ADO Suresh singh
8. Name of the designation of Officer
From the building side : Mr. Sunil Jain
9. Year of Construction : 2011-12
10. Applicant's letter No : (PFW/11)/2012/26804/Addl.Cp/Lic.(Expl.) dated 02.05.12

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	30 m	MR
	Gate width	2.75 m	MR
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	Upper Floor
	Basement
	b. Width of Staircases
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	d. No. of continuous staircases to terrace
	e. Width of Corridor
	f. Door Size
3	Compartmentation.	N/A		
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour
	• Upper floor	12 a/c per hour

	<ul style="list-style-type: none"> Discharge of pump Head of the Pump Power supply Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank
	Overhead Tank capacity
15	Exit Signage.	N/A		
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication in lift car Firemen's grounding switch Lift Signage
17	Standby power supply
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> Total area Location
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Batter backup Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules Delhi Police Act it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ASO*

DO/Estt

Dy CFO

Speare

Submitted for approval please.

11/11/12
24/5/12