

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DPS/MS/2012/2116

Dated: 12/06/2012

FIRE SAFETY CERTIFICATE

Certified that the M/s Footwear (Klick) India Pvt. Ltd located at D-3, Udyog Nagar, New Delhi, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 01.06.2012 in presence of Mr. Subhash Gupta of the factory and that the premises is fit for Class-G (G-1) (Industrial) occupancy with effect from12/06/12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....12/06/12.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

etc

Copy to:
Mr. Subhash Gupta
M/s Footwear (Klick) India Pvt. Ltd
D-3, Udyog Nagar, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated nil received from the Authorized Signatory regarding of NOC in r/o M/s Footwear (Klick) India Pvt. Ltd located at D-3, Udyog Nagar, New Delhi. Premises was inspected & observed that the covered area on each floor 1303.43 m² & 1317.365 m² is comprised of basement & ground floor. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **M/s Footwear (Klick) India Pvt. Ltd** located at D-3, Udyog Nagar, New Delhi.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F6/DFS/MS//BP/2001/2491 dated 09-11-2001
6. Date of inspection : 01-06-2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Sh. Subhas Gupta
9. Year of Construction :
10. Applicant's letter No. : nil dated nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	Provided ✓	M.R. ✓
	• Gate width	5 mtr	Provided ✓	M.R. ✓
	• Width of internal road	4.5 mtr	Provided ✓	M/R ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	4	4 ✓	M.R. ✓
	• Basement	6	provided ✓	M.R. ✓

	b. Width of staircases			
	• Upper Floors	1.25 mtr	Provided ✓	M.R. ✓
	• Basement	1.25 mtr	Provided ✓	M.R. ✓
	c. Protection of exits			
	• Fire check door	Required	Provided ✓	M.R. ✓
	• Pressurization	N.R.	N.R.	N.R. ✓
	d. No. of continuous staircases to terrace	4	4	M.R. ✓
	e. Width of Corridor	Halls only	Halls only ✓	M.R. ✓
f. Door size	1.25 mtrs	1.25 mtrs ✓	M.R. ✓	
3.	Compartmentation.			
	• Fire check door	Required	Provided ✓	M.R. ✓
	• Sealing of electrical shafts	N.R.	N.R.	N.R. ✓
	• Fire Rating of shaft door	N.A.	N.A.	N.R. ✓
	• Water Curtain	N.R.	N.R.	N.R. ✓
	• Fire Dampers	N.R.	N.R.	N.R. ✓
4.	Smoke Management System.			
	• Basements	Required	Exhaust fan provided ✓	M.R. ✓
	• Upper floors	Required	Exhaust fan provided ✓	M.R.
5.	Fire Extinguishers			
	• Total numbers	18	Provided ✓	M.R. ✓
	• Types	ABC & CO ₂ type	provided ✓	M.R. ✓
	• IS marking	required	provided ✓	M.R. ✓

6. First-Aid Hose Rees.				
<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	4		provided	M.R.
	30 m		provided	M.R.
	5 mm		provided	M.R.
7. Automatic fire detection and alarming system.				
<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	N.R.		N.R.	N.R.
	N.R.		N.R.	N.R.
	N.R.		N.R.	N.R.
	N.R.		N.R.	N.R.
	N.R.		N.R.	N.R.
8. MOEFA	N.R.		Not Required	M.R.
9. Public Address System.	Required		Provided	M.R.
10. Automatic Sprinkler system				
<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required		Provided	M.R.
	N.R.		N.R.	N.R.
	No false selling		N.R.	N.R.
11. Internal Hydrants				
<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm		provided	M.R.
	4		provided	M.R.
	4		4	M.R.

12.	Yard Hydrants.			
	• Total number of hydrants	required	4 provided	M.R. ✓
	• Hose Box	4	4	M.R. ✓
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R. ✓
	➤ Head of Main pump	40 mtr	Provided	M.R. ✓
	➤ Number of main pumps	2	Provided	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R. ✓
	➤ Jockey pump head	40 mtr	40 mtr	M.R.
	➤ Standby pump out put	2280 LPM	Provided	M.R.
	➤ Standby pump Head	40 mtr	Provided	M.R. ✓
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	provided	M.R. ✓
	➤ Power supply	Required	100 KVA	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting. ✓			

	Underground tank capacity	50,000	50,000	M.R.
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	30,000 ltr	30,000	M.R.
15	Exit Signage.			
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A.	N.R.	N.R.
	• Pressurization of Lift lobby	N.A.	N.R.	N.R.
	• Communication In lift Car	N.A.	N.R.	N.R.
	• Fireman's Grounding Switch	N.A.	N.R.	N.R.
	• Lift Signage	N.A.	N.R.	N.R.
17.	Standby power supply	Required	100 K.V.A.	M.R.
18.	Refuge Area	N.R.	N.R.	N.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.

	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SUNIL CHAWDHARY

Name

Designation

D.O.

Designation