

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No: F6./DFS/MS/GH/2012/ 2148

Dated: 15/06/12

FIRE SAFETY CERTIFICATE

Certified that the Guest House M/s. Aura Palace, located at 1414-1415, Gali Sangatrashan, Pahar Ganj, New Delhi-110055 comprised of Ground + three and half upper floors with 24 Guest Rooms owned / occupied by M/s Aura Palace guest house have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 04-06-2012 in the presence of Mr. Satish Kumar Mittal and that the building / premises, is fit for occupancy class Group A Sub Division A-I Lodging or Rooming Houses with effect from 15/06/12 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 15/06/12 at New Delhi by.


15/6
of Chief Fire Officer
Delhi Fire Service
A. A. R.

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Sh.Satish Kumar Mittal, M/s Aura Palace, 1414-1415, Gali Sangatrashan, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Aura Palace Guest House, 1414-1415, Gali sangat rashan, Pahar Ganj, New Delhi-110055

2. Type of Occupancy : Residential (Guest house)

3. Type of Case : New Case/Renewal

4. Details of previous NOC : Letter No. - N.A - Dated: - N.A -

5. Fire Safety directives letter No : - NIL -

6. Date of inspection : 04-06-2012

7. Name of the Inspecting Officers : Dharam vir singh yadav

8. Name and designation of officers from the building side : Shri Satish Kumar Mittal.

9. Year of Construction : before to march 2010.

10. Applicant's letter No. : NIL dated 04-05-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks <i>Old Reference</i> MR/NMR <i>P.S. Area.</i>
1	Access to building			
	• Road width	<i>P.S. Area.</i>	<i>04 mtrs to 06 mtrs</i>	<i>M.R.</i>
	• Gate width	<i>1.50 mtrs</i>	<i>1.50 mtrs</i>	<i>M.R.</i>
	• Width of internal road	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	<i>-</i>	<i>one</i>	<i>M.R.</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
b.	Width of staircases			
	• Upper Floors	<i>1.25 mtrs</i>	<i>1.25 mtrs to 1.27 mtrs</i>	<i>M.R.</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
c.	Protection of exits			
	• Fire check door	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Pressurization	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
e.	No. of continuous staircases to terrace			
		<i>-</i>	<i>one</i>	<i>M.R.</i>
g.	Width of Corridor	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
h.	Door Size	<i>-</i>	<i>86 cms x 225 cms</i>	<i>M.R.</i>

contd :-

Aura Palace Guest House
 1414-1415, Gali Sangatleshan,
 Pahar Ganj, New Delhi-110055

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— N.A —		
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— N.A — natural ventilation	— N.A — M.R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	— — ISI marked	Ten (10) ABC & CO2 type yes	M.R M.R M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one yes yes	M.R M.R M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— N.A — — N.A — — N.A — — N.A — — N.A —	— N.A — — N.A — — N.A — — N.A — — N.A —	— N.A — — N.A — — N.A — — N.A — — N.A —
8	MOEFA	yes	Provided	M.R
9	Public Address System.	yes	Provided	M.R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	— N.A —	— N.A —	— N.A —

contd:-

Arua Palace Guest house,
1414-1415, Gali Rangateashan,
Pahar Ganj, New Delhi-110055

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	-N.A.-	-N.A.-	-N.A.-
11	Internal Hydrants	-N.A.-	-N.A.-	-N.A.-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-N.A.-	-N.A.-	-N.A.-
12	Yard Hydrants.	-N.A.-	-N.A.-	-N.A.-
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-N.A.-	-N.A.-	-N.A.-
13	Pumping Arrangements.	-N.A.-	-N.A.-	-N.A.-
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-N.A.-	-N.A.-	-N.A.-
		450 LPM	450 LPM	M.R.
		30 mtrs	30 mtrs	M.R.
		Electric	Electric	M.R.
		-	YES	M.R.
14	Captive Water Storage for fire fighting.	-N.A.-	-N.A.-	-N.A.-
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	-N.A.-	-N.A.-	-N.A.-

contd:-

Aaree Palace Guest House,
14/14-14/15, Gali Sarfateastan,
Palace Ground, New Delhi-110055

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<p style="text-align: center;">yes</p> <p style="text-align: center;">yes</p> <p style="text-align: center;">5000 liter</p>	<p style="text-align: center;">yes</p> <p style="text-align: center;">yes</p> <p style="text-align: center;">5000 liter</p>	<p style="text-align: center;">M.R</p> <p style="text-align: center;">M.R</p> <p style="text-align: center;">M.R</p>
15	Exit Signage.	yes	Provided	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	- N.A -		
17	Standby power supply		D.G. Set	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	- N.A -	- N.A -	- N.A -
19	Fire Control Room	- N.A -	- N.A -	- N.A -
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

Contd.:-

Aruba Palace Guest house,
14/4-1415 Gali' sangatashan,
Pahar Ganj, New Delhi-110055

Signature of the Inspecting Officer

Name

Designation

~~D.O. (Central)~~

~~July 3~~

5/6/12

Signature of the Inspecting Officer

Name *Dheerendra Singh Yadav*

Designation *Asst. Divisional
Officer (Central)*