

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/EH/2012/2193

Dated : 19/06/12

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of McDonald's at ground and Mezzanine floor located at 17 Regal Building, Connaught Palace, New Delhi-110001 comprised of ground and mezzanine floor was granted NOC by this department vide letter No. F6/DFS/MS/EH/2008/1627 dated 16-06-2008. The premises was re-inspected by the officer concerned of this department on 04-06-2012 in the presence of Mr. D.N. Thakur and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy with effect from 19/06/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 19/06/12 at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :

1. M/s Mc Donald's Restaurant, 17, Regal Building, Connaught place, New Delhi-110001
2. Medical officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi-110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : McDonald's Restaurant, (Ground & mezz floor)
17, Regal Building, Connaught Palace
Restaurant (Assembly) New Delhi - 110001

2. Type of Occupancy : _____

3. Type of Case : New Case/ Renewal ✓

4. Details of previous NOC : _____

5. Fire Safety directives letter No : Letter No. F6/DFE/MS/EM/2008/1627 Dated: 16-06-2008

6. Date of inspection : - N.A -

7. Name of the Inspecting Officers : 04-06-2012

8. Name and designation of officers from the building side : Dharmvir Singh Yadav

9. Year of Construction : Shri D. N. Thakur

10. Applicant's letter No. : - N.A -

NIL dated 11-05-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC circulars Requirement	Provided at site	Remarks <u>Old case</u>
1	Access to building			<u>MR/NMR</u>
	• Road width	<u>4.5 mtrs</u>	<u>more than 09 mtrs</u>	<u>M.R</u>
	• Gate width	<u>- N.A -</u>	<u>outer circle</u>	<u>- N.A -</u>
	• Width of internal road	<u>- N.A -</u>	<u>Connaught Place</u>	<u>- N.A -</u>
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	<u>Two Exits</u>	<u>Two at</u>	<u>M.R</u>
	• Basements	<u>- N.A -</u>	<u>mezzanine floor</u>	<u>- N.A -</u>
b.	Width of staircases			
	• Upper Floors	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	• Basements	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
c.	Protection of exits			
	• Fire check door	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
	• Pressurization	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
e.	No. of continuous staircases to terrace	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
g.	Width of Corridor	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>
h.	Door Size	<u>- N.A -</u>	<u>- N.A -</u>	<u>- N.A -</u>

contd:-

Mc Donald's Family Restaurant
 17 Regal Building, Connaught Palace,
 New Delhi - 110001

3	Compartmentation.	— N.A. —		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	/		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	.30 a/c per hour 12 a/c per hour	— N.A. —	— N.A. —
			Exhaust fans provided M.R	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	—	06 (Six)	M.R
		—	ABC & CO ₂ Type	M.R
		ISI marked	yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one	one	M.R
		30 m	yes	M.R
		5 mm	yes	M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— N.A. —		
		/		
8	MOEFA	yes	Provided.	M.R
9	Public Address System.	— N.A. —	— N.A. —	— N.A. —
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	— N.A. —	— N.A. —	— N.A. —

contd:-

Mc Donald's Family Restaurant
 17, Regal Building, Connaught Palace,
 New Delhi-110001

		Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -	- N.A -	- N.A -
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -	- N.A -	- N.A -
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	<p style="text-align: center;">N.A</p> <hr style="width: 100%; border: 1px solid blue;"/>		
		Electric	Electric	M.A
		yes	yes	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -	- N.A -	- N.A -
		- N.A -	- N.A -	- N.A -

contd:-

Mc Donald's Family Restaurant,
17, Regal building, Connaught Palace,
New Delhi-110001.

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	Yes		
		Yes	Yes	M.R
15	Exit Signage.	5,000 litres	5,000 litres	M.R
16	Provision of Lifts.	Yes.	Provided	M.R
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A		
17	Standby power supply	Yes.	D.G. set	M.R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	- N.A -	- N.A -	- N.A -
19	Fire Control Room	- N.A -	- N.A -	- N.A -
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd:-

McDonalds Family Restaurant
17, Regal building, Connaught Palace^(M)
New Delhi - 110001

(5)

Signature of the Inspecting Officer

Name

Designation

~~Do. (Central) [Signature]~~
~~7/06/12~~

~~[Signature]~~
~~07-06-12~~

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
Officer
(Central)