

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 2195

Dated: 19/06/12

FIRE SAFETY CERTIFICATE

Certified that M/s Vinod guest house located at 3820/11, David street, Daryaganj, New Delhi comprised of ground (Reception + shop), first floor (02 guest rooms), second floor (02 guest rooms) and third floor (Dormitory for 06 beds) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/1751 dated 12-06-2009. The premises was re-inspected by the officer concerned of this department on 10-05-2012 in the presence of Mr. Vinod Sehdev, Owner of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from - ~~19/06/12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~19/06/12~~ at New Delhi by.


Dy Chief Fire Officer
for Director
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, M/s Vinod guest house, 3820/11, David street, Daryaganj, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

Old case

INSPECTION REPORT

1. Name & address of the building : Vinod Guest House, 3820/11, David Street, Daryaganj, New Delhi.
2. Type of Occupancy : Lodging House
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FG/DRS/MS/GH/09/1751 Dated: 12/5/2009
5. Fire Safety directives letter No : —
6. Date of inspection : 10/5/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay
8. Name and designation of officers from the building side : Mr. Vinod Sehdev; owner
9. Year of Construction : 1972
10. Applicant's letter No. : 19948/ Addl.CP/42(CH) dated 19/4/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	—	12 mt	MR
	• Gate width	—	Directly accessible from the road	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	—	01	MR being old case
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	1.0 mt	MR being old case
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	Not required	—	—
	• Pressurization	Not required	—	—
	e. No. of continuous staircases to terrace	—	01	MR
	g. Width of Corridor	—	1.0 mt	MR
	h. Door Size	—	0.92 mt	MR
		—	—	—
3	Compartmentation.	Not required	—	—

- GF - Reception + Shop
- FF - 02 Guest rooms.
- SF - 02 Guest rooms
- TF - 01 Dormitory for 06 beds

[Signature]

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.	Not required		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour		
		12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 04 • Types water CO₂, CO₂ • IS marking 	Water CO ₂ CO ₂ ISI marked	provided provided provided	MR MR MR
6	First-Aid Hose Reels.	Not required		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	_____ 30 m 5 mm		
7	Automatic fire detection and alarming system.	Not required		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	Not required.	-	-
9	Public Address System.	Required	provided	MR
10	Automatic Sprinkler System.	Not required		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants	Not required		
	<ul style="list-style-type: none"> • Size of riser/down-comer 	-	-	-

[Handwritten signature]

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants. <i>Not required</i>			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements. <i>Not required</i>			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting. <i>Not required.</i>			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	<i>Required</i>	<i>provided</i>	<i>MR</i>
16	Provision of Lifts. <i>Not required</i>			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	<i>—</i>	<i>—</i>	<i>—</i>

Vinod Guest House, 3820/11, David Street, Darya Ganj, New Delhi

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	—	Inverter provided	M.R
18	Refuge Area.	Not required		
	➤ Total Area			
	➤ Location			
19	Fire Control Room	Not required		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher provided near E / panel.	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ ^{renew} Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Name

Designation

~~DO (Central)~~
 13/06/11 ✓

Signature of the Inspecting Officer

Name M.K. CHATTOPADHYAY

Designation ADO (HG)