

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 2227

Dated: 21/06/12

FIRE SAFETY CERTIFICATE

Certified that the Metropolis Tourist Home Guest House located at 1624-27-34 & 35, Main Bazar, Pahar Ganj, New Delhi-110055 comprised of ground floor (restaurant with separate entry/exit), 1st floor (reception + 12 guest rooms), 2nd floor to 3rd floor (04 guest rooms at each floor + 01 store room + staff kitchen), total 20 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/1388 dated 19-05-2009. The premises was re-inspected by the officer concerned of this department on 11-06-2012 in the presence of Sh. Prashant Sharma (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 20 guest rooms with effect from ...21/06/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/06/12 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049
2. M/s Metropolis Tourist Home, 1624-27-34 & 35, Main Bazar, Pahar Ganj, New Delhi-110055.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Metropolis Tourist Home guest house
1624-27-34 & 35, main Bazar, Palas Cant,
New Delhi - 110055.

2. Type of Occupancy : Residential (Guest House)

3. Type of Case : New Case / Renewal ✓

4. Details of previous NOC : Letter No F6/DFS/MS/GM/2009/388 Dated: 19-05-2009

5. Fire Safety directives letter No : - N.A. -

6. Date of inspection : 11-06-2012

7. Name of the Inspecting Officers : Dharm vir Singh yadav (A.D.O)

8. Name and designation of officers from the building side : Shri Peashant Sharma

9. Year of Construction : 1981 starting year.

10. Applicant's letter No. : M/09-05-2012

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building			old case.
	• Road width	- N.A. -	- N.A. -	- N.A. -
	• Gate width	- N.A. -	- N.A. -	- N.A. -
	• Width of internal road	- N.A. -	- N.A. -	- N.A. -
	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	—	2+2 Total 4 nos.	M.R
	• Basements	- N.A. -	- N.A. -	- N.A. -
b.	Width of staircases			
	• Upper Floors		86 cms to 94 cms G to Terrace	
	• Basements	- N.A. -	85 cms G to Floor 74 cms G to Floor 84 to 88 cms F to Terrace	- N.A. -
c.	Protection of exits			
	• Fire check door	- N.A. -	- N.A. -	- N.A. -
	• Pressurization	- N.A. -	- N.A. -	- N.A. -
c.	No. of continuous staircases to terrace			
g.	Width of Corridor	- N.A. -	- N.A. -	- N.A. -
h.	Door Size	- N.A. -	- N.A. -	- N.A. -

Contd. -

metropolis Tourist Home Guest House,
 1624-27-34 & 35, main Bazar
 Pahar Ganj, New Delhi-110055

old
 case

3	Compartmentation. <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— N.A —		
4	Smoke Management System. <ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— N.A — natural ventilation	— N.A — M.R.
5	Fire Extinguishers <ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 ABC & w. CO2 ISI marked	Ten ABC & w. CO2 Type. yes	M.R. M.R. M.R.
6	First-Aid Hose Reels. <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one. yes yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system. <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— N.A —		
8	MOEFA	— — — yes	Provided- Provided.	— N.A — M.R.
9	Public Address System.			
10	Automatic Sprinkler System. <ul style="list-style-type: none"> • Basement 	— N.A —	— N.A —	— N.A —

contd:-

metropolis Tourist Home Guest House,
 1624-27, 34 & 35, main Bazaar,
 Pahar Ganj, New Delhi - 110055.

old case

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -	- N.A -	- N.A -
11	Internal Hydrants	- N.A -	- N.A -	- N.A -
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N.A	/	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -	/	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N.A	/	
		225 LPM	225 LPM	M.R.
		30 M.	30 M.	M.R.
		Electricity	Electricity	M.R.
		-	starter switch	M.R.
			Provided at G. floor.	M.R.
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -	- N.A -	- N.A -
		- N.A -	- N.A -	- N.A -

contd.

Meteopolis Tourist Home Guest House,
 1624-27-34 & 35, Main Road
 Nehru Place, New Delhi - 110055

		old code		
	> Fire service inlet	- N.A -	- N.A -	- N.A -
	> Access to tank	- N.A -	- N.A -	- N.A -
	• Overhead Tank capacity	2500 litres	2500 litres	M.R
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	- N.A -		
	• Pressurization of Lift lobby	/		
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply	yes	D.G. set	M.R
18	Refuge Area.			
	> Total Area	- N.A -		
	> Location	/		
19	Fire Control Room			
	• Detector System Panel	- N.A -		
	• Flow Switch Panel	/		
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -	- N.A -	- N.A -

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Coated:-


metropolis Tourist Home Guest House,
1624-29 - 34 & 35, main Road,
Patala Ganga, New Delhi - 110055

Signature of the Inspecting Officer

Name

Designation

Do. (contd) ~~19/06/11~~



Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
officer (contd)