

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI - 110001

No: F 6/DFS/MS/2011/ *school/2261*

Dated:- *25/06/12*

FIRE SAFETY CERTIFICATE

Certified that the *M.C. Primary School G-Block Sect-16*
Rohini Delhi 110089 comprised of *Two blocks A & B. A block*
having ground floor & B block of ground + 1 upper floor owned/occupied by *M.C. Primary*
School, G-Block Rohini Delhi. Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *10/5/2012* in the presence of
Smt. Manjula (Principal) and that the building/premises is fit for occupancy
Educational building with effect from *25/06/12* for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *25/06/12* at New Delhi.

Copy to:-

1. *The Principal*
M.C. Primary School
G-Block - Sect. 16, Rohini Delhi

2. *The Director (Edu.)*
M.C.D. Civic Centre
Mintra Road, N. Delhi

[Signature]
25/6
Chief Fire Officer
Delhi Fire Service
[Signature]

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated. In any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

May kindly see the letter No Nil dated 13.02.2012 received from Principal, M.C. Primary School, G-Block, Sector-16, Rohini, Delhi-110 089 from fire safety point of view. Premises was inspected by the ADO (Bawana) on 10.05.2012 & observed that the building is comprised of two blocks A & B. A Block consist of ground floor and B block consist ground plus one upper floor only and having plot area 4150 sq/ meter and covered area is 1550 sq. meter.

The point wise compliance Dte. of Education circular No. F.16/Estate/Fire Safety/CC/2011/3298-3398 dated 01.03.2011, are given below:

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School, G-Block, Sec-16, Rohini
2. Type of Occupancy : School (Education Bldg) A - (G. floor) + B (G+FF)
3. Type of Case : New Case
4. Details of previous NOC : N/A.
5. Fire Safety directives letter No. : F.16/Estate/Fire Safety/CC/2011/3298-3398 Dt. 1.3.2011
6. Date of inspection : 10.05.2012
7. Name of the Inspecting Officers : SHRI RAJMAL KHOKHAR
8. Name and designation of officers : SMT. MANJULA
9. From the building side : PRINCIPAL
10. Year of Construction : 2003
11. Applicant's letter No. : NIL Dated 13/02/2012

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Director of NBC Education Circular Dt. 1.3.11 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	→ Accessible	MR
	• Gate width	→	→	→
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	ONE, if width is 150 cms, otherwise two.	ONE ↗	MR
	• Upper Floors	→	→	→
	• Basement	-	-	-
	b. Width of staircases	150 cms	210 cms ↗	MR
	• Upper Floors	→	→	→
	• Basement	-	-	-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-

d.	No. of continuous staircases to terrace	ONE	ONE	MR
e.	Width of Corridor	1½ Meters	2 meters	—u—
f.	Door size	100 Cms	110 Cms	MR
3.	Compartmentation.			
		NA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.			
		NA		
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers			
	• Total numbers	06	06	MR
	• Types		ABC Type	—u—
	• IS marking	ISI marked	ISI Marked	—u—
6.	First-Aid Hose Rees.			
		NA		
	• Total numbers on each floor	_____	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system.			
		NA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-
8.	MOEFA			
		-	-	-

Public Address System.		Required ^{N/A}	Provided	NA ✓
9.	Automatic Sprinkler system		NA	
	• Basement		-	-
	• Upper Floor		-	-
	• Sprinkler above false ceiling		-	-
11.	Internal Hydrants		NA	
	• Size of riser/down-comer		-	-
	• Number of hydrants per floor		-	-
	• Hose Box		-	-
12.	Yard Hydrants.		NA	
	• Total number of hydrants		-	-
	• Hose Box		-	-
13.	Pumping Arrangements.		NA	
	Ground Level			
	➤ Discharge of main pump		-	-
	➤ Head of Main pump		-	-
	➤ Number of main pumps		-	-
	➤ Jockey Pump out put		-	-
	➤ Jockey pump head		-	-
	➤ Standby pump out put		-	-
	➤ Standby pump Head		-	-
	➤ Auto Starting/Manual stopping		-	-
	➤ Pump Hose Access		-	-
	Terrace level			
	➤ Discharge of pump		-	-
	➤ Head of the pump		-	-
	➤ Power supply		-	-
	➤ Auto Starting of pump		-	-

	Captive Water Storage for fire fighting.			NA
	Underground tank capacity			
	➤ Draw -off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	➤ Overhead Tank Capacity			
15	Exit Signage.	Required v.A. Provided <i>mdh</i>		
16.	Provision of Lifts			NA
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17.	Standby power supply			NA
18.	Refuge Area			NA
	➤ Total Area			
	➤ Location			
19.	Fire Control Room			NA
	➤ Detector System Panel			
	➤ Flow Switch Panel			
	➤ PA system Panel			
	➤ Batter backup			
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:			

✓
The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓
Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number


Signature of the Inspection Officer

Signature of the Inspection Officer

Name SHRI RAJMAL KHOKHAR

Name

Designation ADO

Disignation

50 (N/W)

PI speak



28/5

~~ADP~~
~~Ka...ana~~

Spoken, submitted for approval
plan

50 (N/W)

~~DCFO~~


12/6


ASO