


No. F6/DFS/MS/School/2012/2291

Dated : 26/06/12

FIRE SAFETY CERTIFICATE

Certified that the **ARYA VIDYA MANDIR** located at **PRATAP NAGAR, Delhi-110 007**, comprised of ground plus one upper floor only and less than 9 meters in height, have complied with the fire prevention and fire safety requirement in accordance with Directorate of Education Circular No. F.16/Estate/Fire Safety/CC/2011/3298-3398 dated 01.03.2011 and verified by the officer concerned of fire service on 11.05.2012 in the presence of Joyti Sharma, Vice Principal and that the building/ premises is fit for occupancy class **Educational class** with effect from 26/06/12 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/06/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service
File
Ans
ASD *W*

Smt. Jyoti Sharma, Vice Principal,
ARYA VIDYA MANDIR,
PRATAP NAGAR,
Delhi-110 007.

Copy to :

The Director,
Dte. Of Education,
Old Sectt., Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly see the letter No Nil dated Nil received from Vice Principal, ARYA VIDYA MANDIR, Pratap Nagar, Delhi-110 007 from fire safety point of view. Premises was inspected by the ADO (Bawana) on 11.05.2012 & observed that the building is comprised of ground plus one upper floor only and having plot area 950 sq. meters and covered area is 900 sq. yards. m/s.

The point wise compliance Dte. of Education circular No. F.16/Estate/Fire Safety/CC/2011/3298-3398 dated 01.03.2011, are given below:

INSPECTION REPORT

1. Name & address of the building : ARYA VIDYA MANDIR, PRATAP NAGAR Delhi
2. Type of Occupancy : School
3. Type of Case : New Case
4. Details of previous NOC : N.A
5. Fire Safety directives letter No. : F.16/Estate/Fire Safety/CC/2011/3298-3398 Dt. 1.3.2011
6. Date of inspection : 11.05.2012
7. Name of the Inspecting Officers : Smt. Rajmal Khokhaw, ADO
8. Name and designation of officers : Smt. Jyoti
9. From the building side : Vice Principal
10. Year of Construction : _____
11. Applicant's letter No. : Nil Dated Nil

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Director NBC of Educ circular letter No. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>—</u>	<u>—</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>ONE, if width of stair case is 150 cm. otherwise two.</u>	<u>Two ✓</u>	<u>MR</u>
	• Upper Floors	<u>—</u>	<u>—</u>	<u>—</u>
	• Basement	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>150 cms</u>	<u>130 cms ✓ 100 cms ✓</u>	<u>MR</u>
	• Upper Floors	<u>—</u>	<u>—</u>	<u>—</u>
	• Basement	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>

	d. No. of continuous staircases to terrace	ONE	Two	mk
	e. Width of Corridor	1 1/2 meters	2 meters	u
	f. Door size	100 cms	100 cms	mk
3.	Compartmentation.			
	• Fire check door		NA	
	• Sealing of electrical shafts	-	-	r
	• Fire Rating of shaft door	-	-	r
	• Water Curtain	-	-	r
	• Fire Dampers	-	-	r
4.	Smoke Management System.			
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers			
	• Total numbers	3	Provided 5	mk
	• Types		ABC Type	u
	• IS marking	ISI marked	ISI marked	u
6.	First-Aid Hose Reels.			
	• Total numbers on each floor		NA	
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system.			
	• Type of detectors		NA	
	• Location of Main Panel	-	r	-
	• Location of Repeater Panel	-	r	-
	• Alternate source of power	-	r	-
	• Hooter's Location	-	r	-
8.	MOEFA			
		-	r	r

	Public Address System.	Required ^{N.A.}	Provided	MR ✓
10.	Automatic Sprinkler system		NA	
	• Basement	-	-	-
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants	NA		
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants.	NA		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements.	NA		
	Ground Level			
	➤ Discharge of main pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby pump out put	-	-	-
	➤ Standby pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	➤ Pump Hose Access	-	-	-
	Terrace level			
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power supply	-	-	-
	➤ Auto Starting of pump	✓	✓	✓

14.	Captive Water Storage for fire fighting.			NA
	Underground tank capacity	-	-	-
	➤ Draw -off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	➤ Overhead Tank Capacity	-	-	-
15	Exit Signage.			Required <input checked="" type="checkbox"/> Provided <input checked="" type="checkbox"/> NA <input checked="" type="checkbox"/>
16.	Provision of Lifts			NA
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17.	Standby power supply			NA
18.	Refuge Area			NA
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19.	Fire Control Room			NA
	➤ Detector System Panel	-	-	-
	➤ Flow Switch Panel	-	-	-
	➤ PA system Panel	-	-	-
	➤ Batter backup	-	-	-
	➤ Building Floor plans	-	-	-
20.	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number

Signature of the Inspection Officer

Signature of the Inspection Officer

Name SHRI RAJMAL KHORHAR

Name

Designation ITO

Disignation

DO (NYP)
DEFO.

576112