

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 2280

Dated: 26/06/12

FIRE SAFETY CERTIFICATE

Certified that the Glow Inn Guest House located at 448, Gali Chandiwali, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + 06 guest rooms), 1st floor (07 guest rooms), 2nd floor (08 guest rooms) 3rd floor (10 guest rooms) terrace floor (01 staff room) total 31 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/779 dated 19-03-2009. The premises was re-inspected by the officer concerned of this department on 15-06-2012 in the presence of Sh. Ravinder Pal Singh (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 31 guest rooms with effect from 26/06/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 26/06/12 at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

26/06/12

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049
2. Shri Ravinder Pal Singh M/s **Glow Inn**, 448, Gali Chandiwali, Pahar Ganj, New Delhi-110055

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: Glow Inn Guest House, 448, Gali Chandimali, Pathar Ganj, New Delhi - 110055
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No P6/DFS/MS/GN/2009/779 Dated: 19-03-2009
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 15-06-2012
7. Name of the Inspecting Officer : SI. D.S. Yadav (ADO)
8. Name and designation of Officer from the building side : Sh. Ravinder Pal Singh (Owner)
9. Year of Construction : NA
10. Applicant's letter No. : NIL Dated 08/06/12

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building		<u>P.S. Area</u>	<u>Old Case</u>
	• Road width	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Gate width	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>-</u>	<u>01</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases			
	• Upper floors	<u>-</u>	<u>123cm to 125cm</u>	<u>MR</u>
	• Basements	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	c. Protection of exits			
	• Fire check door	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Pressurization	<u>NA</u>	<u>NA</u>	<u>NA</u>
	d. No of continuous staircase to terrace	<u>-</u>	<u>01</u>	<u>MR</u>

contd.:-

Glow Inn Guest House, 448, Gali Chandiwali, Patna Gauj, N.D.

	e. Width Of Corridor		N/A	NA
	f. Door Size		NA	NA
3.	Compartmentation			
	• Fire check door			/
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain		N/A	
	• Fire Dampers	/		
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	—	10	MR
	• Types	—	Water Co ₂ & ABC. Type	MR
	• IS marking	ISI marked	Yes	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	—	01	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors			/
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power		NA	
	• Hooters' Location	/		
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Yes	Provided	MR
10.	Automatic Sprinkler System			
	• Basements		NA	NA
	• Upper Floor		NA	NA

contd: /

Gilow Inn Guest House, 448, Gali Chandiwal, Pahar Gaurj, N.P.

• Sprinkler above false ceiling	NA	NA	NA
Internal Hydrants			
• Size of riser/down-comer			
• Number of hydrants per floor		NA	
• Hose Box			
12. Yard Hydrants			
• Total number of hydrants	NA	NA	NA
• Hose Box			
13. Pumping Arrangements			
• Ground Level			
• Discharge of main pump			
➤ Head of main pump			
➤ Number of main pumps			
➤ Jockey pump out put			
➤ Jockey pump head		NA	
➤ Standby Pump out put			
➤ Standby Pump Head			
➤ Auto Starting/Manual stopping			
➤ Pump House Access			
• Terrace level	—	225 Lpm	MR
➤ Discharge of pump	—	30 Mtrs.	MR
➤ Head of the pump	Electric	Electric	MR
➤ Power supply		Switch provided	
➤ Auto starting of pump	—	at G.F.	MR
14. Captive water Storage for fire fighting			
• Under ground tank capacity	NA	NA	NA
➤ Draw of connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	—	2500 Liters	MR

contd:-

Glow Inn Guest House, 448, Gali Chandiwala, Pahar Gaj, New Delhi

15	Exit Signage	Yes	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		NA	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17	Standby power supply	Yes	D. G. Set	MR
18	Refuge Area			
	➤ Total area			
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		NA	
	➤ Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 issue ~~shortcomings~~ as noted at serial numbers

Signature of the Inspecting Officer

D.O. (Central)

Name

Designation

Signature of the Inspecting Officer

Name D. S. Yadav

Designation

Assistant Divisional Officer (Central)

20/06/12