

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FG/DFS/MS/School/2012/2282 Dated: 26/06/2012

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Agarsain Public School** located at Ashok Vihar, Phase-IV, Delhi-110052, comprised of basement, Ground + 03 upper floors, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Act 2007 Rules, 2010 and verified by the officer concern of Fire Service on **28/05/2012** in presence of **Mrs. Poonam Gupta (Principal)** of the School and that the premises is fit for **Class-B (Educational)** occupancy with effect from ...26/06/12... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...26/06/12... at New Delhi by


26/6
Chief Fire Officer
Delhi Fire Service


Copy to:

1. Mrs. Poonam Gupta (Principal)
Maharaja Agarsain Public School
Ashok Vihar, Phase-IV, Delhi-110052.
2. The Director of Education, Old Secretariat, Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May kindly peruse letter no. nil dated 03.04.12 received from Sh. Rakesh Kumar Gupta (Working Manager) for **Maharaja Agarsain Public School** located at Ashok Vihar, Phase-IV, Delhi-110052. regarding issue of NOC from fire and safety point of view. The premises was inspected by the undersigned on dated 28.05.12 & observed that the school building is comprised of basement ground plus three upper floors only. However following fire safety measures are put up on the prescribe Performa:

1. Name & address of the building : **Maharaja Agarsain Public School** located at Ashok Vihar, Phase-IV, Delhi-110052.
2. Type of Occupancy : Class -B (Educational)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 28/05/2012
7. Name of the Inspecting Officers : A.D.O. Rajmal Khokhar & D.O. Sunil Chawdhary
8. Name and designation of officers
From the building side : Mrs. Poonam Gupta (Principal)
9. Year of Construction : 1995
10. Applicant's letter No. : nil dated 03.04.12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Required	Provided	M/R
	• Road width	06 mtrs	09 mtr	M/R
	• Gate width	4.5 mtrs	5 mtr	M/R
	• Width of internal road	Required	3 mtrs.	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	4	Provided	M/R

	<ul style="list-style-type: none"> Basement 	3	Provided	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basement 	1.5 mtr	Provided	M/R
	c. Protection of exits	Three 1.5 mtr.	One 1.5 mtr. Two 1.3 mtr each	Meeting the requirement as per the circular of director of edu. Dt. 1-3-2011 copy enclosed.
	<ul style="list-style-type: none"> Fire check door Pressurization 			
	d. No. of continuous staircases to terrace	Required In basement	Provided In basement .	M.R.
		N/R	N/R	M.R.
	e. Width of Corridor	4	Provided	M/R
	f. Door size	2 mtrs.	2.10 mtr	M.R.
		1 mtr	1 mtr	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/R	N/R	Not applicable
		N/R	N/R	Not applicable
		N/R	N/R	Not applicable
		N/R	N/R	Not applicable
		N/R	N/R	Not applicable
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	Exhaust Fans	Provided	M.R.
		N/R	N/R	Not applicable
5.	Fire Extinguishers	Required	Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	31 ISI marked ABC & CO ² type Yes	provided provided provided	M/R M/R M/R



6.	First-Aid Hose Rees.	20 nos.	Provided	M.R.
	<ul style="list-style-type: none"> Total numbers on each floor 	5 nos.	Provided	M/R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	Provided	M/R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Location of Main Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Alternate source of power 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Hooter's Location 	N/R	N/R	Not applicable
8.	MOEFA	Required	Provided	M/R
9.	Public Address System.	Required	Provided	M/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M/R
	<ul style="list-style-type: none"> Upper Floor 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/R	N/R	Not applicable
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> Hose Box 	N/R	N/R	Not applicable
12.	Yard Hydrants.			

	<ul style="list-style-type: none"> • Total number of hydrants 	N/R	Provided	M.R.
	<ul style="list-style-type: none"> • Hose Box 	N/R	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	Not applicable
	➤ Head of Main pump	N/R	N/R	Not applicable
	➤ Number of main pumps	N/R	N/R	Not applicable
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N/R	N/R	Not applicable
	➤ Standby pump Head	N/R	N/R	Not applicable
	➤ Auto Starting/Manual stopping	N/R	N/R	Not applicable
	➤ Pump Hose Access	N/R	N/R	Not applicable
	Terrace level			
	➤ Discharge of pump	450 LPM 900 LPM	Provided	M/R
	➤ Head of the pump	40 mtr	Provided	M/R
	➤ Power supply	Required	N/P	M.R.
	➤ Auto Starting of pump	N/R	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable

	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	15,000 ltrs	provided	M.R.
15	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable
	• Pressurization of Lift lobby	N/A	N/A	Not applicable
	• Communication In lift Car	N/A	N/A	Not applicable
	• Fireman's Grounding Switch	N/A	N/A	Not applicable
	• Lift Signage	N/A	N/A	Not applicable
17.	Standby power supply			
18.	Refuge Area			
	➤ Total Area	N/R	N/R	Not applicable
	➤ Location	N/R	N/R	Not applicable
19.	Fire Control Room			
	➤ Detector System Panel	N/R	N/R	Not applicable
	➤ Flow Switch Panel	N/R	N/R	Not applicable
	➤ PA system Panel	N/R	N/R	Not applicable
	➤ Batter backup	N/R	N/R	Not applicable
	➤ Building Floor plans	N/R	N/R	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....


Signature of the Inspection Officer

Signature of the Inspection Officer


Name RAJ KUMAR KHOSLA

Name

Designation A.D.O

Designation

SO (P.H)



11