

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 2293

Dated : 26/06/12

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of. Pargati Food court, Restaurant located at ground floor, Pargati Maidan, New Delhi-110001 owned / occupied by M/s. Pargati Restaurant comprised of ground floor, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service rules, 2010 and verified by the officer concerned of fire service on 12-06-2012 in the presence of Mr S.K Goyal manager of Restaurant and building is fit for occupancy for restaurant with effect from...26/06/12... for a period of three years in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 26/06/12... at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :

1. General Manage I. T. P. O., Pargati Bhawan, Pargati Maidan, New Delhi- 110001
2. M/s Pargati Food Court Reataurant, Pargati Maidan, New Delhi-110001.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : Pragati Food court Restaurant,
Pragati maidan, New Delhi-110001
 2. Type of Occupancy : Restaurant (Assembly)
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. - N.A - Dated: - N.A -
 5. Fire Safety directives letter No : - N.A -
 6. Date of inspection : 12-06-2012
 7. Name of the Inspecting Officers : Dharm vir singh yadav (A.20)
 8. Name and designation of officers from the building side : Shri S.K. Goyal (manager)
 9. Year of Construction : May 2010
 10. Applicant's letter No. : NIL (Dialy No 3389 14-03-12)

No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BML Requirement	Provided at site	Remarks
1	Access to building			M/R/NM/R
	• Road width	12 mter	12 mter	M.R
	• Gate width	04.5 mter	05 mter	M.R
	• Width of internal road	06 mter	06 mter	M.R
Number, Width, Type & Arrangement of Exits				
a. Number of staircases		- N.A -	- N.A -	
• Upper Floors		/	/	
• Basements				
b. Width of staircases				
• Upper Floors				
• Basements				
c. Protection of exits				
• Fire check door				
• Pressurization				
c. No. of continuous staircases to terrace				
g. Width of Corridor				
h. Door Size		1.5/02 mter	2 mter & 1.5 mter	M.R

(K)

contd:-

*Pragati Food court Restaurant,
Pragati maidan, New Delhi-110001.*

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— N.A —		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors (<i>Ground only</i>) 	30 a/c per hour 12 a/c per hour	— N.A —	— N.A — <i>Provided Exhaust fans M.R</i>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	— — ISI marked	<i>Ten (10)</i> <i>ABC & CO₂ type</i> <i>yes</i>	<i>M.R</i> <i>M.R</i> <i>M.R</i>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	— 30 m 5 mm	<i>Existing in Pragati maidan near gate of Restaurant</i> <i>yes</i>	<i>M.R</i> <i>M.R</i> <i>M.R.</i>
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— N.A —		
8	MOEFA	<i>Existing</i>	<i>Already Existing</i>	<i>M.R.</i> <i>M.R</i>
9	Public Address System.	<i>Existing</i>	— II —	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	— N.A —	— N.A —	— N.A —

Contd. :-

*Pragati Food court Restaurant,
Pragati maidan, New Delhi - 110001*

	<ul style="list-style-type: none"> Upper Floor <i>Restaurant at Ground floor only.</i> Sprinkler above false ceiling 	- N.A -	- N.A -	- N.A -
11	Internal Hydrants	- N.A -	- N.A -	- N.A -
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Already existing near Gate	Already existing near Gate	M.R
		Available	Already Available	M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Already Existing in compound Yes	Already Existing in compound Yes	M.R M.R
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head <i>Diesel driven Sprinkler pump</i> Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	— — one — — 2850 LPM Head: 70m yes. — yes. — — — — — N.A	2850 LPM 70 mts one 280 LPM 70 mts 2850 LPM 2850 LPM 2250 LPM yes. yes. — — — — — — — —	M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	Existing in the Pragati maidan 2,00,000 Liters		M.R
		Already Existing	Already Existing	M.R

contd.

*Pragati Food court Restaurant,
Pragati maidan, new Delhi-110001.*

<i>Existing in P. maidan</i>			
	<i>Required</i>	<i>Provided</i>	<i>(M.R)</i>
<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<i>Existing</i>	<i>Existing</i>	<i>(M.R)</i>
15 Exit Signage.	<i>- N.A -</i>	<i>- N.A -</i>	<i>+ N.A -</i>
16 Provision of Lifts.	<i>Required</i>	<i>Provided</i>	<i>(M.R)</i>
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<i>- N.A -</i>		
17 Standby power supply	<i>Required</i>	<i>Provided</i>	<i>(M.R)</i>
18 Refuge Area.			
<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	<i>- N.A -</i>		
19 Fire Control Room			
<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	<i>Already Existing in entire Pragati maidan.</i> <i>Yes.</i> <i>Yes.</i> <i>- N.A -</i>	<i>Already Existing in entire Pragati maidan.</i> <i>Yes.</i> <i>Yes.</i> <i>- N.A -</i>	<i>M.R</i> <i>M.R</i> <i>M.R</i> <i>M.R</i> <i>M.R</i>
20 Special Fire Protection Systems for Protection of special Risks, if any:	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd. -

Pragati Food court Restaurant.
Pragati maidan, New Delhi-110001.

Signature of the Inspecting Officer

Name

Designation

D.O. (Central) JY

19/06/12 ✓


Signature of the Inspecting Officer

Name Dharmvir Singh Yadav.

Designation Assistant Divisional
officer (Central)