

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2012/School/2315

Dated:- 27/06/12

FIRE SAFETY CERTIFICATE

Certified that the Balleshwar Memorial Public School G-Block
Prem Nagar I Deen 110041 comprised of Ground + one
upper floor owned/occupied by three
Balleshwar Education Society Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on 4/5/2012 in the presence of
Mr. Shambhu Nath and that the building/premises is fit for occupancy
Educational building with effect from 27/06/12 for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 27/06/12 at New Delhi.


26/6
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Head Master
Balleshwar Memorial
Pub. School G-Block Prem Nagar I
Deen 110041
2. The Director of Edu.
Govt. of NCT of Delhi
old Sectt Deen

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non - functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Performa for Compliance of shortcoming.

INSPECTION REPORT

1. Name & address of the building Baleshwer Public School, G-Block, Prem Nagar-I
2. Type of Occupancy Educational (Kisari) Delhi-88
3. Type of Case ∴ New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No F-16/estate/cc/f.safety/11/3298-3398 dt. 1-3-2011
6. Date of inspection 04/5/12
7. Name of the Inspecting Officers : ADO-SHYAM LAL
8. Name and designation of officers Sh. Shambhu Nath Bhagat (H.M)
from the building side : _____
9. Year of Construction 2002 (G+1)
10. Applicant's letter No. Nil dated 20-3-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Director of Edm Requirement 1/3/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	03.7m	M/R
	• Gate width	-do-	03 m	M/R
	• Width of internal road	-do-	N/R	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	M/R
	• Basements	Nil	Nil	-
	b. Width of staircases	1.5 m	1.5 m & 95 cm	M/R
✓	• Upper Floors	1.5 m	-do-	M/R
	• Basements	Nil	Nil	-
	c. Protection of exits			
	• Fire check door		N/R	
	• Pressurization		✓	
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	R	1.5	M/R
	h. Door Size	1 m	1 m	M/R

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				NIR
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			NIR
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	300 m ² covered area for one ABC or CO ₂ (Risky) ISI marked Ext.	8 ✓		MIR
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm			NIR
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				NIR
8	MOEFA				NIR
9	Public Address System.				NIR
10	Automatic Sprinkler System.				NIR
	<ul style="list-style-type: none"> • Basement 				NIR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			NIR
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			NIR
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			NIR
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			NIR
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			NR
16	Provision of Lifts.			N/A
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			NIR
18	Refuge Area.			N/A
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			NIR
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			Nic

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

D.O (NW)

Shortcoming at ser no. 2 (b) complied by school 10.

ventured 21/5

Shyam Lal
15/5/2012
(SHYAM LAL)
Assist. Dirn officer

note. Speak