

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.

No. F6/DFS/MS/ *EH/2012/2326*

Dated *28/6/12*

FIRE SAFETY CERTIFICATE

Certified that **Barbeque Nation Restaurant at Eros Cinema building, Jangpura Extn., New Delhi-110014** at Ground Floor **Owned/Occupied** by Barbeque Nation Restaurant have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire on 11.06.2012 in the presence of Mr. Manoj Sharma, Manager of the restaurant and that the premises is fit for occupancy class- "Assembly" with effect from *28/6/12* for a period of **Three years**, subject to conditions as mentioned below.

Issued on *28/6/12* at New Delhi by

28/6
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
of
Man

Copy to: -

1. Manager, Barbeque Nation Restaurant,
Eros Cinema building, Jangpura Extn., New Delhi-110014

Conditions for the validity of Fire Safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : BARBEQUE NATION RESTAURANT at
 : EROS CINEMA BUILDING,
 : JANGPURA EXTN., NEW DELHI-110014
2. Type of Occupancy : Restaurant / Eating House
3. Type of Case : New
4. Details of previous NOC : Nil. Dt. _____
5. Fire Safety Directives letter No : NO: F6/DFS/MS/BP/2005/13 dt 07/01/05
6. Date of Inspection : 11.06.2012
7. Name of the Inspecting Officer : Rajan Kladehna, ADO/Mrd.
8. Name and designation of the Officers from the building side : Mr. Manoj Sharma
9. Year of Construction : _____ (Resht. at Ground Floor of East Mall Hotel.)
10. Applicant's letter No. : Nil dt 14/5/2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15 mtr.	15 mtr. ✓	M/R
	• Gate width	5 mtr	5 mtr. ✓	M/R
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase		N/A	
	➤ Upper floors			
	➤ Basement			
	• Width of Staircase		NA	
	➤ Upper floors			
	➤ Basement			
	• Protection of Exits			
	➤ Upper floors	Required	Provided ✓	M/R
	➤ Basement	NA	NA	NA
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size	NA	NA	NA

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required NA NA NA NA	Provided / NA NA NA NA	M/R NA NA NA NA
4	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour 12 a/c Per hour	NA Provided /	NA M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	One /300 m ² ABC / CO ₂ ISI mark	10 Nos ABC - 5 Nos CO ₂ - 5 Nos yes	M/R M/R M/R
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	1 /Per Floor 30 m 5mm	Provided / Provided / Provided /	M/R M/R M/R
7	Automatic Fire Detection and Alarming System			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 		Provided / Provided / NA 1000 kVA NA	M/R M/R NA M/R NA
8	MOEFA			
		Required	Provided /	M/R
9	Public Address System			
			NA	
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA Required NA	NA Provided / NA	NA M/R NA
11	Internal Hydrant			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	150 mm 1 1	150 mm / 1 1	M/R M/R M/R
12	Yard Hydrant			
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 	4 4	4 4	M/R M/R

13	Pumping Arrangements			
	Ground Level			
	➤ Number of main pump	1	1	MIR
	➤ Discharge of main pump	2850 LPM	2850 LPM	MIR
	➤ Head of main pump	60 mts	70 mts	MIR
	➤ Jockey pump out put	100 LPM	180 LPM	MIR
	➤ Jockey pump Head	60 mts	70 mts	MIR
	➤ Standby pump out put	2850 LPM	2850 LPM	MIR
	➤ Standby Pump Head	60 mts	70 mts	MIR
	➤ Auto Starting/Manual stopping	Auto	Auto	MIR
	➤ Pump House Access	Required	Provided	MIR
	Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MIR
	➤ Head of the pump	45 m	45 m	MIR
	➤ Power Supply	1000 kVA	1000 kVA	MIR
	➤ Auto starting /Manual stopping	Auto	Auto	MIR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	2,00,000 Lts	2,00,000 Lts	MIR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead tank capacity	30,000 Lts	30,000 Lts	MIR
15	Exit Signage	Required	Provided	MIR
16	Provision of Lifts		NA	
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply	1000 kVA	1000 kVA	MIR
18	Refuge Area		NA	
	• Total Area			
	• Location			
19	Fire Control Room		NA	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			

20	Special Fire Protection System for Protection of special risk, if any	Required	Provided 4 ABC FIRE	M/R
----	---	----------	------------------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number.....

DO (South)

[Handwritten signature]
ASST. DIV. OFFICER

[Handwritten signature]
Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER