

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. FC(DFS) MS/Club/2012/2339

Dated 29/06/12

FIRE SAFETY CERTIFICATE

Certified that the East End Club, FC-13, CBD Ground, Karkardooma Court Road, Delhi-32, comprised of basement ground plus two upper floors was granted NOC by this department vide letter No.F.6/DFS/MS/09/736 dated 17.03.09. The premises was re-inspected by the officer concerned of this department on 20.06.12 in the presence of Mr. Madan (Electrician), and found that the Assembly Building have deemed complied with the fire prevention and fire safety requirements in accordance with the earlier directives and that the building is fit for occupancy Group D-6 "(Eating House)" with effect from29.6.12 renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....29/6/12.....at New Delhi by


29/6
Chief Fire Officer
Delhi Fire Service

Copy to-

1. Mr. Manoj jain,
Assistant Commissioner (Excise),
Office of The Commissioner of Excise, Entt. & Luxury Tax,
L-Block: Vikas Bhawan: I.P. Estate: New Delhi
2. Mr. Lalit Mohan Bansal,
East End Club, FC-13, CBD Ground, Karkardooma Court Road, Delhi-32

dc
29/6/12

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : East End Club, FC-13, CBD Ground, Karkardooma Court Road, Delhi-32
2. Type of Occupancy : Assembly (Eating House)
3. Type of Case : Renewal
4. Details of Previous NOC : Letter No- F.6/DFS/MS/898 Dated 25.03.10
5. Fire Safety direction letter No : Old requirements
6. Date of Inspection : 20.06.12
7. Name of the Inspecting Officers: : Suresh singh (ADO)
8. Name of the designation of Officer
from the building side : Mr. Madan (Electrician)
9. Year of Construction : 2002
10. Applicant's letter No : F.1(Excise/Club/2010-2011/371 dated 23.01.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	Provided at Site	Old Accepted
1	Access to building		
	Road width	45 m	Old Accepted
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	Old Accepted
	Upper Floor	2 no.	Old Accepted
	Basement	2 no.	Old Accepted
	B. Width of Staircases	1.8 & 1 m	Old Accepted
	Upper Floor
	Basement	1.7 & 0.85 m	Old Accepted
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
	g. Width of Corridor
	h. Door way	2 m	Old Accepted
3	Compartmentation.	Required	Provided	
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement
	• Upper floor

5.	Fire Extinguisher			
	• Total numbers	08 no.	Old Accepted
	• Types	Co2 & ABC	Old Accepted
	• IS marking	ISI marked	Old Accepted
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	Old Accepted
	Length of hose reel hose	30 m	Old Accepted
	Nozzle diameter	5 mm	Old Accepted
7	Automatic fire detection and alarming system. N/A			
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	N/A
9	Public address System.	N/A
10	Automatic Sprinkler System.	Required	Provided	
	basement	Provided	Old Accepted
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants			
	size of riser/down-comer	80 mm	Old Accepted
	Number of hydrants per floor	2 no.	Old Accepted
	Hose Box	2 no.	Old Accepted
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.			
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump	450 LPM	Old Accepted
	➤ Head of the Pump	40 m	Old Accepted

East End Club

	➤ Power supply
	➤ Auto Starting of pump
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	15000 Liters	Old Accepted
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity	10000 Liters	Old Accepted
15	Exit Signage.	Provided	Old Accepted
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply		Yes	Old Accepted
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010

Singh
Signature of the Inspecting Officer
Name *Suresh Singh*
Designation *ADD*

Def (E)

Recommended for approval please.

Singh
20/01/12