

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS; DELHI FIRE SERVICE; CONNAUGHT PLACE; NEW DELHI


NO F6/DFS/MS/motel/2012/2331

Dated 29/6/12

FIRE SAFETY CERTIFICATE

Certified that Just Chill Water & Fun Park located in Sydney Grand Hotel Pvt Ltd, Village Singhola, Delhi comprised of Change rooms, Costume Shop, different Water rides, wave pool, rain dance only owned and occupied by Sh. Rajinder Aggarwal Authorised signatory Sydney grand Hotel Pvt Ltd (Just Chill Water & fun Park). The Fire safety Certificate have already been issued vide letter no. F6/DFS/MS/2011/motel/52 dated 11.01.11. There is no change in the building construction and found complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 23.6.11 in the presence of Sh. Sanjay kumar and that the building/premise is fit for occupancy under the provision of Rules 113 of regulation for licensing and controlling places of public Amusement (Other than Cinema) and performance of Public Amusement 1980 with effect from the date of issue of this letter for a period of three years in accordance with the Rules 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/6/12 at New Delhi.


Chief Fire Officer
Delhi Fire Service.

Copy to:-

1. The Addl. CP (Lic),
First Floor, Police Station,
Defence Colony,
New Delhi.
2. Authorised Signatory,
Sydney Grand Motel
Kh no. 6/6, (0-12), 6/7 (0-10),
6/14 (0-16), 6/1794-80, 6/18 (4-8),
6/1991-2, 6/16 (1-2) & 6/15 (3-4)
Village Singhola, Delhi.

INSPECTION REPORT

1. Name & address of the building : Just chill water & Fun Park located in Sydney
2. Type of Occupancy : Assembly place Ground Hotel Pvt Ltd, Vill-Singhola, main G.T. Road, Delhi
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 23.6.12
7. Name of the Inspecting Officers : Do Vipin Kental
8. Name and designation of officers from the building side : Sanjay Kumar
9. Year of Construction : _____
10. Applicant's letter No. : 31506-14/Adm. C.P./N.C. (Amst) Delhi 28.5.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<small>Under Amusement Act Requirement (Other than cinema)</small>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>P</u>	<u>M/R</u>
	• Gate width	<u>5 mt</u>	<u>P</u>	<u>M/R</u>
	• Width of internal road	<u>6 mt</u>	<u>P</u>	<u>M/R</u>
2	Number, Width, Type & Arrangement of Exits	<u>N/A</u>		
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 No. ABC type. ISI marked	P	MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 m 5 mm	P " "	MIR " "
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
		R/N/A	P	MIR
9	Public Address System.			
		N/A		
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 		N/A	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	1	P	MIR
		1	P	,
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		1620 LPM	NOC already issued to motel bldg. resort
			Three	
			1800 LPM	
			1620 UPM	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	50,000 L	P	MIR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 				
15	Exit Signage.		R	P	MR
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A			
17	Standby power supply		R	P	MR
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A			
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A			
20	Special Fire Protection Systems for Protection of special Risks, if any:				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Ventel
Signature of the Inspecting C

Name *VIPIN KENTAL*

Designation *DO N.W.*