

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT LANE : NEW DELHI

No. FC/DFB/MS/2012/2334

Dated: 29/6/12

FIRE SAFETY CERTIFICATE

Certified that the M/s Rolex Products located at J-31, Sector-2, DSIDC Bawana, Delhi-110039 comprised of basement, ground and two upper floors only having height more than 9 meters and area more than 250 m² have complied with the fire prevention and fire safety requirement under Rule 33 of Delhi Fire Service Rules, 2010 and Delhi Fire Service Act, 2007 and verified by the officer concerned of fire service on 21.05.2012 in the presence of Shri Suresh Kumar, Proprietor and that the building/premises is fit for occupancy class **Industrial Building (G-2)** class with effect from 29/6/12 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/6/12 at New Delhi by.

Shri Suresh Kumar Proprietor,
M/s ROLEX PRODUCTS,
J-31, Sector-2, DSIDC,
Bawana, Delhi-110039.


29/6
Chief Fire Officer
Delhi Fire Service.

QC

29/6/12

Copy to :-

Asstt. Drugs Controller & Licensing Authority,
Govt of NCT of Delhi, Drugs Control Department,
F-17, Karkardooma, Delhi-32.

Following fire safety directives must be adhered to :-

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regards to construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building Bye-laws.
6. This certificate cannot be treated in any case for regularization of unauthorized construction, unauthorized use of land if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This available on www.dfs.delhigovt.nic.in.

May kindly see the letter No F.615/COS/MFG/DC/793 dated 25.04.2012 received from Asstt. Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, Drugs Control Department, F-17, Karkardoma, Delhi-110032 from fire safety point of view. The premises was inspected by the ADO (Bawana) on 21.05.2012 & observed that the building is comprised of basement, ground plus two upper floors only and having plot area 150 sq meters and covered area is 150 sq. meters.

The point wise compliance of the safety recommendations as per Delhi Fire Service Act, 2007 & Delhi Fire Service, Rules, 2010, are given below:

INSPECTION REPORT

1. Name & address of the building : M/S. ROLEX PRODUCT, J-31, Sec-2, DSIDC BAWANA
2. Type of Occupancy : INDUSTRIAL BUILDING (G-2)
3. Type of Case : NEW CASE
4. Details of previous NOC : NA
5. Fire Safety directives letter No. : DPS ACT, 2007 & DPS Rules 2010
6. Date of inspection : 21.05.2012
7. Name of the Inspecting Officers : Shri Rajneel Khokhar, ADO
8. Name and designation of officers : Shri Suresh Kumar
from the building side Proprietor
9. Year of Construction : 2005
10. Applicant's letter No. : F.615/COS/MFG/DC/793 Dt- 25.04.12

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>Accessible</u>	<u>MR</u>
	• Gate width	<u>————</u>	<u>————</u>	<u>————</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	<u>ONE</u>	<u>ONE</u>	<u>MR</u>
	• Upper Floors	<u>————</u>	<u>————</u>	<u>————</u>
	• Basement	<u>————</u>	<u>————</u>	<u>————</u>
b.	Width of staircases	<u>125 cms</u>	<u>130 cms</u>	<u>MR</u>
	• Upper Floors	<u>————</u>	<u>————</u>	<u>MR</u>
	• Basement	<u>————</u>	<u>————</u>	<u>MR</u>
c.	Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>

	d. No. of continuous staircases to terrace	ONE	ONE	MR
	e. Width of Corridor	100 cms	100 cms	MR
	f. Door size			
3.	Compartmentation.	NA		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.	NA		
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers			
	• Total numbers	8	12	MR
	• Types		ABC Type	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	Four (one at each floor including basement)	Provided	MR
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system.	NA		
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-
8.	MOEFA	-	-	-

9.	Public Address System.	Required	Provided	MR
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants	NA		
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	5	5	5
	• Hose Box	2	2	2
12.	Yard Hydrants.	NA		
	• Total number of hydrants	1	1	1
	• Hose Box	1	1	1
13.	Pumping Arrangements.	NA		
	Ground Level			
	➤ Discharge of main pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby pump out put	-	-	-
	➤ Standby pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
	➤ Pump Hose Access	-	-	-
	Terrace level			
	➤ Discharge of pump	900 lpm	900 lpm	MR
	➤ Head of the pump	40 mhs	40 mhs	MR
	➤ Power supply	-	-	-
	➤ Auto Starting of pump	-	✓	✓

14.	Captive Water Storage for fire fighting.			NA
	Underground tank capacity	-	-	-
	➤ Draw -off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	➤ Overhead Tank Capacity	10,000 litres	10,000 Litres	MR
15	Exit Signage.			Requised Provided MR
16.	Provision of Lifts			NA
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17.	Standby power supply			NA
18.	Refuge Area			NA
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19.	Fire Control Room			NA
	➤ Detector System Panel	-	-	-
	➤ Flow Switch Panel	-	-	-
	➤ PA system Panel	-	-	-
	➤ Batter backup	-	-	-
	➤ Building Floor plans	-	-	-
20.	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number



Signature of the Inspection Officer

Signature of the Inspection Officer

Name

SHRI RAJMAL KHOKHAR

Name

Designation

ASST. DIV. OFFICER

Designation

SOC NW/)

DCFO

28/5