

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

NO.F6/DFS/MS/ *School/2012/2333*

Dated: *29/6/12*

FIRE SAFETY CERTIFICATE

Certified that **Tagore Modern Public School**, located at **Motia Khan**, near **DESU office**, **New Delhi-55** comprised of basement (storage), ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 08.06.2012 alongwith Mrs. , Principal and that the building/premises is fit for occupancy class group B (Educational building) with effect from ~~*29/6/12*~~ for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~*29/6/12*~~ at New Delhi by.

  
*29/6*  
Chief Fire Officer  
Delhi Fire Service.

*QC*  
*29/6/12*

Copy to: -

1. The Director of Education, Govt .of NCT of Delhi, Old secretariat, Delhi
2. The Hony. Secretary, Tagore Modern Public School, Motia Khan, near DESU office, New Delhi-55

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : Tagore Modern public School, Moli'a Khan,
2. Type of Occupancy : Lodging House Near DESU Office, New Delhi.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No.            Dated:
5. Fire Safety directives letter No : As per NBC-IV
6. Date of inspection : 5/6/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO(HO)
8. Name and designation of officers  
from the building side : Mrs Meena Kumari Principal
9. Year of Construction : 1990
10. Applicant's letter No. : nil dated 28/1/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	—	8 mt ✓	MR
	• Gate width	—	5 mt ✓	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02 ✓	MR
	• Basements	02	02 ✓	MR
	b. Width of staircases	—	—	—
	• Upper Floors	1.5 mt / Two per floor	1.30 mt, 1.77 mt ✓	MR
	• Basements	1.5 mt / Two per floor	1.30 mt, 1.77 mt ✓	MR
	c. Protection of exits	—	—	—
	• Fire check door	Not required	Basement stairs are directly opening to outside	—
	• Pressurization	Not required	—	—
	e. No. of continuous staircases to terrace	02	02	MR ✓
	g. Width of Corridor	—	1.5 mt	MR ✓
	h. Door Size	—	1.5 mt	MR ✓
		—	—	— ✓
3	<b>Compartmentation.</b>	Not required	—	— ✓



	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>				
4	<b>Smoke Management System.</b>				
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	Exhaust fans provided	MR	
		12 a/c per hour	Open & not required	MR	
5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ISI marked	provided	MR	
			provided	MR	
			provided	MR	
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01	provided & functional	MR	
		30 m	provided & functional	MR	
		5 mm	provided & functional	MR	
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>				
8	<b>MOEFA</b>	Not required	—	—	
9	<b>Public Address System.</b>	Not required	—	—	
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	provided	MR	
		Not required	—	—	
		Not required	—	—	
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	Not required	—	—	

MP

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		—	—	—
		900 LPM	900 LPM	MR
		—	40 mt	MR
		—	—	—
		—	Starting switch provided at GF	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
		15,000 lbs.	15,000 lbs.	MR
15	<b>Exit Signage.</b>	Required	provided	MR
16	<b>Provision of Lifts.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	—	—	—

*[Handwritten signature]*

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b> <i>Not required</i>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	<b>Fire Control Room</b> <i>Not required</i>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	<i>Required</i>	<i>ABC type fire extinguisher found provided near E/P panel</i>	<i>MR</i>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name *M.K. Chattopadhyay*

Designation

Designation *ADO(HO)*

*DO (Central)*  
*25/06/12*