

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2012/ 2357

Dated: 03/07/12

FIRE SAFETY CERTIFICATE

Certified that the **Nursery School of Krishna Geetanjali Foundation Society (Regd.)** located at Sec-10, Phase-I, Dwarka, New Delhi-110075 comprised of basement, stilt, ground floor plus two upper floors, having total 21 Rooms (Including Class Rooms, Staff Room, Office, Reception, Sports Room & Store etc.) owned/ occupied by the Management of Krishna Geetanjali Foundation Society (Regd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 30.06.2012 in the presence of Sh. V.P. Tandon (President). The building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....03/07/12..... at New Delhi.

CHIEF FIRE OFFICER
For DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Sh. V.P. Tandon (President),
Krishna Geetanjali Foundation Society (Regd.),
Sec-10, Phase-I, Dwarka, New Delhi-110075.
(Ref. No. KGFS 2550 dated 09.05.2012.)

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Basement, Stilt, Ground plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : Nursery School of Krishna Greetanjali Foundation Soc. (Regd)
2. Type of Occupancy : Educational (School) Sec-10, Ph-I, Dwarka, N.D-75.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date _____
5. Fire Safety directives letter No : N/A
6. Date of inspection : 30.06.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. V. P. Tandon
9. Year of Construction : 2011-2012
10. Applicant's letter No. : KGFS 2550 dated 09.05.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	12mtr	MR
	• Gate width	-	06mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	Two	Two ✓	MR
	• Upper Floors	-do-	-do- ✓	MR
	• Basements	-do-	-do- ✓	MR
b.	Width of staircases			
	• Upper Floor	150cms	151cms, 90cms ✓	MR
	• Basements	-	160cms, 123cms ✓	MR
c.	Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
d.	No. of continuous staircases to terrace	-	One ✓	-
e.	Width of Corridor	-	150cms ✓	-
f.	Door Size	-	110cms x 210cms ✓	-
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fans are provided ✓	MR
	• Upper floors		Natural Ventilation ✓	MR


		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Three at each floor	Provided ✓	MR
	• Types	A.B.C	- do - ✓	MR
	• IS marking	ISI marked	ISI marked ✓	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided ✓	MR
	• Length of hose reel hose	30 m	- do - ✓	MR
	• Nozzle diameter	5 mm	- do - ✓	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	-	D.G. Set of 125kva ✓	MR
	• Hooters' Location	-	-	-
8.	MOEFA			
		N/A	-	-
9.	Public Address System			
		N/A	-	-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided ✓	MR
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer ✓	-	100 m.m ✓	MR
	• Number of hydrants per floor	-	One ✓	MR
	• Hose Box	-	One ✓	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-
		N/A	-	-

Sec-10, Phase-I, Dwarka,
N.D - 110075.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		02 Nos 450 LPM Each	Provided ✓	MR
		30M Each	- do -	MR
		Required	- do -	MR
		-	Both	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	Provided ✓	MR
		N/A	-	-
		15000 Ltr	15000 Ltr ✓	MR
15.	Exit Signage.	Required	Provided ✓	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	Required	Provided ✓	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided ✓	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



Signature of Inspecting Officer

Name H.L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asstt. Divisional Officer.