

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. P6/DFS/MS/Firework/2012/2361


Dated: 04/07/2012

FIRE SAFETY CERTIFICATE

Certified that the M/s Ajeet Traders, Shop No 178, Shivaji Market, Tagore Garden Extn., New Delhi-27 proposed for running the trade of Sale and Possession of 300 Kgs Fire Works and 1200 Kg Chinese sparkles at the ground floor of a building owned / occupied by Smt Rajwant Kaur, have complied with the fire prevention and fire safety Requirements in accordance with Guidelines issued by Additional Commissioner of Police (Lic.) and verified by the officer concerned of fire service on 22/05/2012 in the presence of Sh Gurbachan Singh and that the Shop is fit for occupancy Class Fire Works with effect from 04/07/12 for a period of three years subject to conditions given below.

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional of fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock when shop is open.
4. Any deviation w.r.t. construction etc shall be verified by concerned building sanctioning authority.
5. This certificate may not be treated in any case for regularization of unauthorized construction, if any.

Issued on 04/07 /2012 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi w.r.t letter No (PFW / 13 / 2012) / 28450-52 / Addl. CP/Lic. (Expl.), dated 14/05/2012
2. Smt Rajwant Kaur, H. No BA-301, GF, Tagore Garden, New Delhi 27.

1. Name & address of the building : M/s Ajeet Traders, Shop NO 178,
Shivaji market, Tagore Garden Extn, Delhi - 27
2. Type of Occupancy : storage (Explosive)
3. Type of Case : New Case / Renewal
4. Details of previous NOC : Letter No. NIL Dated: —
5. Fire Safety directives letter No : NBC
6. Date of inspection : 22/05/2012
7. Name of the Inspecting Officers : ADO SSTuli'
8. Name and designation of officers
from the building side : Sh Gurbachan Singh (Smt Rajwanti kaur)
9. Year of Construction : —
10. Applicant's letter No. : (PFW/13/2012)/28450-52/Addl.CP Lic (Expl)
dtl 14/5/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtrs	Provided	m/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A

5	Fire Extinguishers					
	• Total numbers	04 NOS 02 ABC 02 WCO ₂	04	m/R		
	• Types	ISI marked	02 ABC 02 WCO ₂	m/R		
	• IS marking		yes	m/R		
6	First-Aid Hose Reels.			N/R	NP	
	• Total numbers on each floor	—	— " —	— " —		
	• Length of hose reel hose	30 m	— " —	— " —		
	• Nozzle diameter	5 mm	— " —	— " —		
7	Automatic fire detection and alarming system.			N/R	N/A	NP
	• Type of detectors	— " —	— " —	— " —		
	• Location of Main Panel	— " —	— " —	— " —		
	• Location of Repeater Panel	— " —	— " —	— " —		
	• Alternate source of power	— " —	— " —	— " —		
	• Hooters' Location	— " —	— " —	— " —		
8	MOEFA			N/R	N/A	NP
9	Public Address System.			— " —	— " —	— " —
10	Automatic Sprinkler System.			N/R	N/A	NP
	• Basement	— " —	— " —	— " —		
	• Upper Floor	— " —	— " —	— " —		
	• Sprinkler above false ceiling	— " —	— " —	— " —		

	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 mtr	Provided	m/r
3	Compartmentation.	N/R	N/A	N/P
	• Fire check door	- " -	- " -	- " -
	• Sealing of electrical shafts	- " -	- " -	- " -
	• Fire Rating of shaft door	- " -	- " -	- " -
	• Water Curtain			
	• Fire Dampers	- " -	- " -	- " -
4	Smoke Management System.	N/R	N/A	N/P
	• Basements	30 a/c per hour	- " -	- " -
	• Upper floors	12 a/c per hour	- " -	- " -

11	Internal Hydrants	N/R	N/A	N/P
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	— " —	— " —	— " —
		— " —	— " —	— " —
		— " —	— " —	— " —
12	Yard Hydrants.	N/R	N/A	N/P
	<ul style="list-style-type: none"> • Total number of hydrants 	— " —	— " —	— " —
	<ul style="list-style-type: none"> • Hose Box 	— " —	— " —	— " —
13	Pumping Arrangements.	N/R	N/A	N/P
	<ul style="list-style-type: none"> • Ground Level 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Head of Main pump 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Number of main pumps 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Jockey pump head 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	— " —	— " —	— " —
	<ul style="list-style-type: none"> ➤ Pump House Access 	— " —	— " —	— " —

	Terrace level	N/R	N/A	N/P
	➤ Discharge of pump	- " -	- " -	- " -
	➤ Head of the pump	- " -	- " -	- " -
	➤ Power Supply	- " -	- " -	- " -
	➤ Auto Starting of pump	- " -	- " -	- " -
14	Captive Water Storage for fire fighting.	N/R	N/A	N/P
	• Underground tank capacity	- " -	- " -	- " -
	➤ Draw-off connection	- " -	- " -	- " -
	➤ Fire service inlet	- " -	- " -	- " -
	➤ Access to tank	- " -	- " -	- " -
	• Overhead Tank capacity	- " -	- " -	- " -
15	Exit Signage.	Required	Provided	N/R
16	Provision of Lifts.	N/R	N/A	N/P
	• Pressurization of Lift Shaft	- " -	- " -	- " -
	• Pressurization of Lift lobby	- " -	- " -	- " -
	• Communication In lift Car	- " -	- " -	- " -
	• Fireman's Grounding Switch	- " -	- " -	- " -
	• Lift Signage	- " -	- " -	- " -

17	Standby power supply	N/R	N/A	N/A
18	Refuge Area.	- " -	- " -	- " -
	➤ Total Area	- " -	- " -	- " -
	➤ Location	- " -	- " -	- " -
19	Fire Control Room	N/R	N/A	NP
	• Detector System Panel	- " -	- " -	- " -
	• Flow Switch Panel	- " -	- " -	- " -
	• PA System Panel	- " -	- " -	- " -
	• Batter backup	- " -	- " -	- " -
	• Building Floor Plans	- " -	- " -	- " -
20	Special Fire Protection Systems for Protection of special Risks, if any:	- " -	- " -	- " -

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

DO (MWD) Jm

Ami 25/6

Signature of the Inspecting Officer

Name

Designation

SSTuli
19/6/12
ADO (MW)
AD (west)