

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 2365

Dated : 04/07/12

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of. Pargati Restaurant located at basement (storage) and ground floor (restaurant) Pargati Maidan, New Delhi-110001 owned / occupied by M/s. Pargati Restaurant comprised of basement and ground floor, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service rules, 2010 and verified by the officer concerned of fire service on 12-06-2012 in the presence of Mr Jasvinder manager of Restaurant and building is fit for occupancy for restaurant with effect from 04/07/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 04/07/12 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :

1. General Manage I. T. P. O., Pargati Bhawan, Pargati Maidan, New Delhi- 110001
2. M/s Pargati Reataurant, Pargati Maidan, New Delhi-110001.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: Pragati Restaurant, Pragati Maidan, New Delhi - 110001
2. Type of Occupancy : Restaurant (Assembly)
3. Type of Case : New.
4. Details of previous NOC : Letter No - N.A -
5. Fire Safety directives Letter No. : - N.A -
6. Date of inspection : 12-06-2012
7. Name of the Inspecting Officer : Dharm vir singh yadav.
8. Name and designation of Officer from the building side : Ms. Jasvinder (manager)
9. Year of Construction : Before to January 2010
10. Applicant's letter No. : Disty no 3390 dt. 14-03-2012

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtes	12 mtes	M.R
	• Gate width	04.5 mtes	05 mtes	M.R
	• Width of internal road	- N.A -	06 mtes	M.R
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	- N.A -	- N.A -	- N.A -
	• Basements	-	03	M.R
	b. Width of staircases			
	• Upper floors	- N.A -	- N.A -	- N.A -
	• Basements	-	01.5 mtes 01.25 mtes 01.10 mtes	M.R
	c. Protection of exits			
	• Fire check door	- N.A -	- N.A -	- N.A -
	• Pressurization	- N.A -	- N.A -	- N.A -
	d. No of continuous staircase to terrace	- N.A -	- N.A -	- N.A -

contd.:-

*Pragati Restaurant, Pragati maidan,
New Delhi - 110001*

	e. Width Of Corridor	- N.A -	- N.A -	- N.A -
	f. Door Size	01.5 mtrs	(1) Exit Gate = 2 mtrs (2) Exit Gate = 1.12 mtrs (3) Exit Gate = 1.00 mtr	M.R
3.	Compartmentation			
	• Fire check door	N.A		
	• Sealing of electrical shafts	/		
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	Yes, (Exhaust Fan)	M.R.
	• Upper floors	12 a/c per hour	Exhaust fans provided.	M.R.
5.	Fire Extinguishers			
	• Total numbers	-	10 (Ten)	M.R
	• Types	-	ABC CO ₂ & W. CO ₂ type	M.R
	• IS marking	ISI marked	I.S.I. mark	M.R
6.	First - Aid Hose Reels			
	• Total numbers on each floor	Already Existing in the Pragati maidan compound	Existing in the Pragati maidan Area near the Gate of Restaurant	M.R
	• Length of hose reel hose			M.R
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	Heat/Smoke	M.R
	• Location of Main Panel	Gr. Floor.	Gr. Floor.	M.R
	• Location of Repeater Panel	- N.A -	- N.A -	- N.A -
	• Alternate source of power	Battery Backup near the Exit Gate.	Battery back up near the Exit Gate	- M.R -
	• Hooters' Location			- M.R -
8.	MOEFA	Yes.	Provided.	M.R
9.	Public Address System	Already Existing	Already Existing	M.R
10.	Automatic Sprinkler System			
	• Basements	- N.A -	Provided	M.R
	• Upper Floor	- N.A -	Provided.	M.R

covered area of the basement is less than 20 sq mtr.

Pragati Restaurant
Pragati maidan, New Delhi - 110001

	• Sprinkler above false ceiling	— N.A —	— N.A —	— N.A —
Internal Hydrants				
	• Size of riser/down-comer	Already Existing	Already Existing	M.R.
	• Number of hydrants per floor	Near Gate	Near Gate	M.R.
	• Hose Box	Available	Already Available	M.R.
12.	Yard Hydrants			
	• Total number of hydrants	Already Existing	Already Existing	M.R.
	• Hose Box			M.R.
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	—	2850 LPM	M.R.
	➤ Head of main pump	—	70 mtes	M.R.
	➤ Number of main pumps	one	one	M.R.
	➤ Jockey pump out put	—	280 LPM	M.R.
	➤ Jockey pump head	70 mtes	70 mtes	M.R.
	➤ <i>Speed Kicker Pump (1)</i> head = 70 m.	—	2250 LPM	M.R.
	➤ Standby Pump out put <i>(Diesel Driven)</i>	— 2850 —	2850 LPM	M.R.
	➤ Standby Pump Head	70 mtes	70 mtes	M.R.
	➤ Auto Starting/Manual stopping	Auto starting	yes	M.R.
	➤ Pump House Access	yes	yes	M.R.
	• Terrace level	— N.A —	—	
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power supply			
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	2,00,000 litres	2,00,000 litres	M.R.
	➤ Draw of connection	Already Existing	Already Existing	M.R.
	➤ Fire service inlet	yes	yes	M.R.
	➤ Access to tank	yes	yes	M.R.
	• Overhead Tank capacity	Already Existing	10,000 litres	M.R.

contd.:-

*Peagati Restaurant,
Peagati maidan, New Delhi-110001*

		<i>Required</i>	<i>Provided</i>	<i>M.R</i>
15	Exit Signage			
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	<i>N.A</i>		
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17	Standby power supply	<i>Required</i>	<i>Available</i>	<i>M.R</i>
18	Refuge Area			
	➤ Total area	<i>N.A</i>		
	➤ Location			
19	Fire control room			
	➤ Detector system panel	<i>N.A</i>		
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any;	<i>N.A</i>		<i>N.A</i>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 ~~issue~~ ~~shortcomings~~ as noted at serial numbers

Signature of the Inspecting Officer

Name

S.O. (Central)

Designation

10/06/12

Signature of the Inspecting Officer

Name

Dharmvir Singh Yadav

Designation

Assistant Divisional Officer