

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT LANE
NEW DELHI-110 001.

No. F.6/DFS/MS/08/2382/2008/2411

Dated : 06/07/12

FIRE SAFETY CERTIFICATE

Certified that the **McDonald Family Restaurant** located at **Ground & First Floor, M2K Multiplex, Pitam Pura, Community Centre, Road No. 44, New Delhi-110 034** was issued NOC vide this office letter No. F.6/DFS/MS/08/2382 dated 31.10.2008, have complied with the fire prevention and fire safety requirement in accordance with Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 22.06.2012 in the presence of Shri Atul Kukreja, Manager and that the building/ premises is fit for occupancy class **Assembly Building (Class D)** with effect from 06/07/12 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/07/12 at New Delhi by

4
3/7
Chief Fire Officer
Delhi Fire Service

Shri Atul Kukreja, Manager,
McDonald Family Restaurant,
M2K Multiplex, Pitam Pura,
Community Centre, Road No. 44, New Delhi-110 034

Copy to :

The Fire Officer,
M2K Multiplex, Pitam Pura,
Community Centre, Road No. 44, New Delhi-110 034

M/s. Connaught Plaza Management Pvt. Ltd.,
13 A, Jor Bagh, New Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly see the letter No. Nil dated 13.04.2012 received from Shri Harish Sharma, McDonalds Restaurant, at Ground & First Floor, M2K Multiplex, Pitam Pura, Community Centre, Road No. 44, New Delhi-110 034 for renewal of NOC from fire safety point of view. The Restaurant has already issued NOC vide letter No. F.6/DFS/MS/08/2382 dated 31.10.2008. Premises was inspected by the ADO (Bawana) on 22.06.2012 & observed that the McDonalds Rastaurant is located at ground floor. & first floor.

The point wise compliance as per Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010, are given below:

INSPECTION REPORT

1. Name & address of the building : MCDONALD'S FAMILY RESTAURANT, PITAMPURA
2. Type of Occupancy : RESTAURANT, ASSEMBLY BUILDING (CLASS A)
3. Type of Case : RENEWAL
4. Details of previous NOC : F.6/DFS/MS/08/2382 Dt. 31.10.2008
5. Fire Safety directives letter No. : DFC ACT 2007 & DFS RULES, 2010
6. Date of inspection : 22.06.2012
7. Name of the Inspecting Officers : SHRI RAJMAL KHOKHAR ADO
8. Name and designation of officers From the building side : SHRI ATUL KUKERAJA, MANAGER,
9. Year of Construction : _____
10. Applicant's letter No. : NIL Dated 13.04.2012

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	<i>Renewal, already NOC issued F.6/DFS/MS/08/2382</i>		
	• Road width	<i>Accessible</i>	<i>Accessible</i>	<i>MR</i>
	• Gate width	<i>— —</i>	<i>— —</i>	<i>— —</i>
	• Width of internal road	<i>-</i>	<i>-</i>	<i>-</i>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<i>Two</i>	<i>Two</i>	<i>MR</i>
	• Upper Floors	<i>— —</i>	<i>— —</i>	<i>— —</i>
	• Basement	<i>-</i>	<i>-</i>	<i>-</i>
	b. Width of staircases	<i>Regurd</i>	<i>125 cmg 150 cmg</i>	<i>MR</i>
	• Upper Floors	<i>— —</i>	<i>— —</i>	<i>MR</i>
	• Basement	<i>-</i>	<i>-</i>	<i>-</i>
	c. Protection of exits	<i>-</i>	<i>-</i>	<i>-</i>
	• Fire check door	<i>-</i>	<i>-</i>	<i>-</i>

5.	d. No. of continuous staircases to terrace	Pw+	Pw	md
	e. Width of Corridor	-	-	-
	f. Door size	100 cm	-	-
3.	Compartmentation.		NA	
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System.		NA	
	• Basements	-	-	-
	• Upper floors	-	-	-
5.	Fire Extinguishers		Required & Provided by M&H	
	• Total numbers	Required	Provided	MR
	• Types		-u-	-u-
	• IS marking	ISI marked	-u-	-u-
6.	First-Aid Hose Rees.		Required & Provided by M&H	
	• Total numbers on each floor		Required	Provided MR
	• Length of hose reel hose	30 m	-u-	-u-
	• Nozzle diameter	5 mm	-u-	-u-
7.	Automatic fire detection and alarming system.		NA	
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooter's Location	-	-	-
8.	MOEFA		Required	Provided MR

9.	Public Address System.	-	-	-
10.	Automatic Sprinkler system	Required	Provided MA	MR
	• Basement	-	-	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants	Required	Provided	MR
	• Size of riser/down-comer	-	by the	-
	• Number of hydrants per floor	-	MA	-
	• Hose Box	-	-	-
12.	Yard Hydrants.		NA	
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby pump out put			
	➤ Standby pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump Hose Access			
	Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power supply			
	➤ Auto Starting of pump			

MA

by the

Provided

14.	Captive Water Storage for fire fighting.	Provided by the M&M		
	Underground tank capacity			
	➤ Draw -off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	➤ Overhead Tank Capacity	Required	Provided	md
15	Exit Signage.	Required	Provided	md
16.	Provision of Lifts	NA		
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17.	Standby power supply	Required	Provided	md
18.	Refuge Area	NA		
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19.	Fire Control Room	NA		
	➤ Detector System Panel	-	-	-
	➤ Flow Switch Panel	-	-	-
	➤ PA system Panel	-	-	-
	➤ Batter backup	-	-	-
	➤ Building Floor plans	-	-	-
20.	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

✓
The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓
Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....
.....


Signature of the Inspection Officer

Signature of the Inspection Officer

Name SHRI RAJMAL KHOKHAR

Name

Designation ADO
SO (M.N.)

Disignation

