

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2012 / 2350

Dated 03/07/12

FIRE SAFETY CERTIFICATE

Certified that the Commercial Complex (Vardhman Diamond Plaza), located at Plot No. 3, Motia Khan, Desh Bandhu Gupta Road, Pahar Ganj, New Delhi, comprised of Basement + Ground + Three upper floors (Basement – Storage, Ground floor – Shops, Upper floors – Offices) was inspected by the officers concerned of this department on 29.05.2012 in the presence of Shri Balbir Singh and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for class occupancy "Mercantile" with effect from - 31/7/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 31/7/12 at New Delhi by


S. 37
Chief Fire Officer
Delhi Fire Service.

Copy to:-

1. The Secretary, (VDP Unit Holders Welfare Assn.) Vardhman Diamond Plaza, Plot no 3, DDA, Community Centre, Motia Khan D.B. Gupta Road, New Delhi.
2. The Addl. Comm. of Police (Lie) First Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

Commercial complex (Vardhaman Diamond Plaza)
Plot No. 3, Motia Khan, Desbandhu Gupta

Road, Pahar Ganj, New Delhi - 110055

Mercantile cum office.

1. Name & address of the building :
 2. Type of Occupancy
 3. Type of Case
 4. Details of previous NOC
 5. Fire Safety directives letter No
 6. Date of inspection
 7. Name of the Inspecting Officers
 8. Name and designation of officers from the building side
 9. Year of Construction
 10. Applicant's letter No.
- : New Case/ Renewal
- : Letter No. - N.A - Dated - N.A
- : F6/m.s/DES/B.9/1181 dated 30-05-2003
- : 29-05-2012
- : Dharm vir singh yadav (A.D.O)
- : Shri Balbir Singh (President)
- : Prior to 2009

No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 05 mtrs - N.A -	30 mtrs / m.R 12 mtrs / m.R - N.A -	m.R m.R - N.A -
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Two Four plus one ramp	Two / Four plus one ramp /	m.R m.R
b.	Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	AS PER BPL 1983 1.25 mtrs 1.25 mtrs	1.45 to 1.5 mtrs 1.45 to 1.5 mtrs	m.R m.R
c.	Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required in Basement - N.A -	Provided () - N.A -	m.R - N.A -
e.	No. of continuous staircases to terrace			
g.	Width of Corridor			
h.	Door Size			

AS PER
BPL 1983

contd--

commercial complex (Vardhaman Diamond
Plot No 3, Motia Khan
Dehbandi Ghat Road,
Pahar Ganj, New Delhi - 110055
Date 23/2/2023)

3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-	N.A - N.A - N.A - N.A - N.A -	N.A - N.A - N.A - N.A - N.A -
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 		30 a/c per hour 12 a/c per hour	Basement not in use Natural ventilation M.R.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 		ISI marked	24 Nos M.R. ABC & CO2 type M.R. Yes M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 		Two 30 m 5 mm	Two M.R. Yes M.R. Yes M.R.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			N.A ✓
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 		Yes	Yes M.R.

contd:-

commercial complex (Westhaven Diamond Plaza)
Plot no 3 Motia Khan,
Desh Banda Gupta Road,
Patel Ghat, New Delhi-110057

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	yes - N.A -	yes - N.A -	M.R - N.A -
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100/150 MM one yes	- 100/150 MM one yes	M.R M.R M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A - - N.A -	- N.A - - N.A -	- N.A - - N.A -
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put ^(diesel driven) Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	1620 LPM 60 mtrs One 180 LPM — 1620 LPM 60 m yes yes N.A	1620 LPM 60 mtrs one 180 LPM 53 mtrs 1620 LPM 60 m yes yes —	M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	50,000 liters yes	50,000 liters yes	M.R M.R M.R

commercial complex (Vardhaman diamond
Plot no 3, Motia Khan, Plaza)
Desh Bandhu Gupta Road,
New Delhi - 110055.

	✓ Fire service inlet	yes	yes	M.R
	✓ Access to tank	yes	yes	M.R
	✓ Overhead Tank capacity	10,000 litres	10,000 litres	M.R
15	Exit Signage.	yes	Provided	M.R
16	Provision of Lifts. (One Lift)	Ground to third floor		
	✓ Pressurization of Lift Shaft	- N.A -	- N.A -	- N.A -
	✓ Pressurization of Lift lobby	- N.A -	- N.A -	- N.A -
	✓ Communication In lift Car	yes	yes	M.R
	✓ Fireman's Grounding Switch	yes	yes	M.R
	✓ Lift Signage	yes	yes	M.R
17	Standby power supply	yes	D.G set 40KVA	M.R
18	Refuge Area.			
	✓ Total Area	- N.A -		
	✓ Location	/		
19	Fire Control Room			
	✓ Detector System Panel	- N.A -		
	✓ Flow Switch Panel			
	✓ PAI System Panel			
	✓ Batter backup			
	✓ Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -	- N.A -	- N.A -

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted in serial number

Note:- Basement is used only for fire pump house criticized
remaining part of the basement is vacant and not in use.

commercial complex (Vedhman diamond Plaza)
Plot no 3, Moti Khan,
Desh Bandhu Gupta Road,
New Delhi - 110055.

Signature of the Inspecting Officer

Name

Designation

Do (central) by
31/05/12

gopal
Signature of the Inspecting Officer

Name *Dharam Singh Yadav*

Designation *Assistant Divisional
Officer
(Central)*