

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No: F6/DFS/MS/2012/Auditorium/2459

Dated: 10/07/12

FIRE SAFETY CERTIFICATE

Certified that the Auditorium in the name and style of M/s. **FICCI Auditorium** located at Tansen Marg, New Delhi is comprised of a basement (Storage/Services) and ground floor was granted NOC by this department vide letter No. F6/DFS/MS/Audi/2010/750 dated 11-03-10. The premises was re-inspected by the officer concerned of this department on 26-06-2012 in the presence of Mr. Rakesh Swami, Director and found that the said auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy with effect from ...10/07/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/07/12 at New Delhi by.


**CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Defence Colony Police Station,
First Floor, Defence Colony, New Delhi, 110049.
2. The Director, **FICCI Auditorium**, Tansen Marg, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : F.I.C.C.I Auditorium, Federation House, Tansen marg, New Delhi-110001

2. Type of Occupancy : Auditorium / Assembly

3. Type of Case : New Case / Renewal

4. Details of previous NOC : Letter No F6/M.S/D.F.S/Auditorium/10750 Dated: 11-03-10

5. Fire Safety directives letter No : - N.A -

6. Date of inspection : 26-06-2012

7. Name of the Inspecting Officers : Dheem vee singh yadav

8. Name and designation of officers from the building side : Shri Rakesh swami (Director)

9. Year of Construction : - N.A -

10. Applicant's letter No. : N/A (dt 7-05-12) old case

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | N.A | more than 12 mtrs | M.R |
| | • Gate width | N.A | 05 mtrs | M.R |
| | • Width of internal road | N.A | N.A | N.A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | N.A | N.A | N.A |
| | • Basements | — | 3 staircases & 2 Ramps | M.R |
| | b. Width of staircases | | | |
| | • Upper Floors | N.A | N.A | N.A |
| | • Basements | N.A | N.A | N.A |
| | c. Protection of exits | | | |
| | • Fire check door | yes | Provided | M.R |
| | • Pressurization | N.A - | N.A | M.A |
| | e. No. of continuous staircases to terrace | — | one spiral staircase + iron ladder | M.R |
| | g. Width of Corridor | N.A | N.A | |
| | h. Door Size | N.A | N.A | N.A |

contd. -

old case

| | | | | |
|----|---|-----------------|--------------------------------------|-----|
| 3 | Compartmentation. | | | |
| | • Fire check door | yes | Provided | M.R |
| | • Sealing of electrical shafts | yes | Provided | M-R |
| | • Fire Rating of shaft door | N.A | N.A | N.A |
| | • Water Curtain | N.A | N.A | N.A |
| | • Fire Dampers | yes | Provided | M-R |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | yes | M.R |
| | • Upper floors | 12 a/c per hour | yes | M.R |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | — | 16 (sixteen) | M.R |
| | • Types | — | ABC 5kg. CO2 4.5kg W.CO2 9 litres | M.R |
| | • IS marking | ISI marked | yes | M.R |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | — | Total 9 hose reels | M-R |
| | • Length of hose reel hose | 30 m | yes | M-R |
| | • Nozzle diameter | 5 mm | yes | M-R |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | smoke/heat | smoke/heat | M.R |
| | • Location of Main Panel | Gr. Floor. | Gr. Floor | M.R |
| | • Location of Repeater Panel | N.A | N.A | N.A |
| | • Alternate source of power | Battery back-up | Battery Back up | M.R |
| | • Hooters' Location | — | near the Gate | M.R |
| 8 | MOEFA | yes | Provided | M.R |
| 9 | Public Address System. | yes | Provided. | M.R |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | yes | Provided | M.R |

contd: -

F.I.C.C.I Auditorium,
Tansen marg, New Delhi - 110001

old
case

| | | | | |
|----|---|--|--|--|
| | <ul style="list-style-type: none"> Upper Floor <i>Ground floor Auditorium</i> Sprinkler above false ceiling | — | Provided | M.R |
| 11 | Internal Hydrants | N.A | N.A | N.A |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | — | 150 M.M & 100 M.M | M.R |
| | | — | Five at Ground floor | M.R |
| 12 | Yard Hydrants. | — | yes | M.R |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | — | 10 | M.R |
| | | 10 | 10 | M.R |
| 13 | Pumping Arrangements. | <i>Pump house is common i.e. for National Museum for Natural History & F.I.C.C.I.</i> | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump | <ul style="list-style-type: none"> 2850 LPM 70 mtes one 180 LPM 40 mtes 2850 LPM 70 mtes yes yes N.A N.A N.A N.A N.A | <ul style="list-style-type: none"> 2850 LPM 70 mtes one 180 LPM 40 mtes 2850 LPM 70 mtes Provided Provided N.A N.A N.A N.A N.A | <ul style="list-style-type: none"> M.R M.R M.R M.R M.R M.R M.R M.R M.R N.A N.A N.A N.A N.A |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection | <ul style="list-style-type: none"> 50,000 litres yes | <ul style="list-style-type: none"> 50,000 litres Provided | <ul style="list-style-type: none"> M.R M.R |

contd:-

F.I.C.C! Auditorium,
Tansen marg, New Delhi-110001

old
case

| | | | | |
|----|--|--|--|----------------------------------|
| | <ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | <p>yes</p> <p>yes</p> <p>5000 litres</p> | <p>Provided</p> <p>Provided</p> <p>5000 litres</p> | <p>M.R</p> <p>M.R</p> <p>M.R</p> |
| 15 | Exit Signage. | yes | Provided | M.R |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N.A | N.A | N.A |
| | • Pressurization of Lift lobby | N.A | N.A | N.A |
| | • Communication In lift Car | N.A | N.A | N.A |
| | • Fireman's Grounding Switch | N.A | N.A | N.A |
| | • Lift Signage | N.A | N.A | N.A |
| 17 | Standby power supply | yes | D.G. set 110KVA | M.R |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N.A | N.A | M.R |
| | ➤ Location | N.A | N.A | M.R |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | yes | Provided | M.R |
| | • Flow Switch Panel | yes | Provided | M.R |
| | • PA System Panel | yes | Provided | M.R |
| | • Batter backup | yes | Provided | M.R |
| | • Building Floor Plans | yes | Provided | M.R |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N.A | N.A | N.A |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue ~~shortcomings~~ as noted at serial numbers.....

contd :-

FICCI Auditorium,
Tansen Marg, New Delhi-110001

Signature of the Inspecting Officer

Name

Designation

D.O. (Central) / J.S.
5/07/12

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional
Officer
(Central)