

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 2462

Dated: 10/07/12

FIRE SAFETY CERTIFICATE

Certified that M/s Meharan guest house located at 2293, Gali Qasim Jan, Ballimaran, Delhi comprised of ground floor (Commercial use), first floor (Reception + 06 guest rooms), second (07 guest rooms) & third floor (08 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/09/410 dated 10-02-2009. The premises was re-inspected by the officer concerned of this department on 18-06-2012 in the presence of Moinuddin, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from ----- ~~10/07/12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~10/07/12~~ at New Delhi by.


Chief Fire Officer
for Director
Delhi fire service


Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, M/s Meharan guest house, 2293,Gali Qasim Jan, Ballimaran, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

87 d case.

INSPECTION REPORT

1. Name & address of the building : Mehran Guest House, 2293, Gali Qasim Jan, Ballimaran, Delhi
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/GH/09/410 Dated: 10-02-2009
5. Fire Safety directives letter No : No.
6. Date of inspection : 18-06-2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO
8. Name and designation of officers
from the building side : Moinuddin, Manager
9. Year of Construction : 1989
10. Applicant's letter No. : Nil dated 25-04-2012

Details of Building:- Ground (Commercial use) + 1st floor(6 rooms + reception) + 2nd floor (7 rooms) + 3rd floor (8 rooms)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts (special area)	6 mts	MR
	• Gate width	-----	Direct access from the road	MR
	• Width of internal road	-----	-----	-----
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	-----	01	MR
	• Basements	-----	-----	-----
	b. Width of staircases			
	• Upper Floors	0.90 mts	1.07 mts	MR
	• Basements	-----	-----	-----
	c. Protection of exits			
	• Fire check door	-----		MR
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	-----	01	-----
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.0 mts	1.25 mts	MR
3	Compartmentation.			
	• Fire check door	Not required	-----	-----
		-----	No electrical shaft	-----

J

Meharun Guest House, 2293, Gali Qabirganj,
Balli Maram, Delhi

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-----	-----	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	-----	-----
			Open & not required	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Water CO ₂ -4 CO ₂ type-4 ISI marked	provided provided provided	MR MR MR
6	First-Aid Hose Reels.	Not required		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	Provided at 1 st & 3 rd floor and functional Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.	Not required		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA	Not required	-----	-----
9	Public Address System.	Required	Provided and functional	MR
10	Automatic Sprinkler System.	Not required		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants	Not required		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.	Not required		
	<ul style="list-style-type: none"> Total number of hydrants 	—	—	—

[Handwritten signature]

	• Hose Box	—	—	—
13	Pumping Arrangements.	Not required		
	• Ground Level			
	➤ Discharge of main Pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	225 LPM	Provided & functional	MR
	➤ Head of the pump	—	30 mts	MR
	➤ Power Supply	Required	provided	MR
	➤ Auto Starting of pump	Required	Starting switch provided at reception	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	2500 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not applicable		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply	Not Required	-----	-----
18	Refuge Area.	Not applicable		
	➤ Total Area	—	—	—

[Handwritten signature]

	➤ Location			
19	Fire Control Room	Not required		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 CO ₂ type fire extinguishers found Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer


Name

Designation

Signature of the Inspecting Officer

Name (M.K. CHATTOPADHYAY)

Designation :- Assistant Divisional Officer

DO (CO) 
3/8/12