

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No F6/DFS/MS/EH/2012/ 2506

Dated: 11/07/12

**FIRE SAFETY CERTIFICATE**


Certified that the .Mc. Donald family Restaurant at shop No 98 & 107.V3S Mall. Plot no 12, Laxmi Nagar Distt.Center, Vikas Marg, Delhi being run at ground floor of the bldg. was granted NOC by this deptt. Vide letter No. F6 /DFS /MS /EH / 2007/ 3794/ Dated 24.12.2007. The Premises was re-inspected by the officer concerned of this department on 29.05.2012 in the presence of Mr. D.N.Thakur have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of Restaurant at ground floor with effect from 11/07/12 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service, 2010 printer overleaf .

Issued on 11/07/12 at New Delhi.

  
CHIEF FIRE OFFICER  
FOR DIRECTOR  
DELHI FIRE SERVICE

Copy to :-

1. Shri Harish Sharma Connaught Plaza Resturants Pvt.Ltd.,  
13 A, Jor Bagh Market,  
New Delhi-110003.
2. The dy. Health Officer,  
Shahdara South Zone,

  
11.7.12

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

**INSPECTION REPORT**

1. Name & address of the building : McDonalds Restaurant at Shop no.98 & 107, V3S Mall,Plot no.12, Laxmi Nagar, District Centre, Delhi .
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/EH/2009/670 dated 05.03.09.
5. Fire Safety directives No : NBC
6. Date of Inspection : 29.05.12
7. Name of the Inspecting Officer : ADO Gurmukh Singh.
8. Name of the designation of Officer  
From the building side : Sh.D.N.Thakur
9. Year of Construction : 2004
10. Applicant's letter No : CPRPL/FM/NOC/2011-12/19 dated 16.04.12

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12 Mtrs 4.5 Mtrs. -----	26 Mtrs. 4.5 Mtrs. -----	MR MR -----
2	Number, Width, Type and Arrangement of Exits	NA	NA	
	a. Number of Staircases	-----	-----	-----
	• Upper Floor	-----	-----	-----
	• Basement	-----	-----	-----
	B. Width of Staircases	-----	-----	-----
	• Upper Floor	-----	-----	-----
	• Basement	-----	-----	-----
	c. Protection of exits	-----	-----	-----
	• Fire check door	-----	-----	-----
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	-----	-----	-----
	g. Width of Corridor	2.5 Mtrs	2.5 Mtrs	MR
	h. Door Size	2.0 Mtrs.	3. nos.(1.0 M ,2.0 Mtrs., & 80 CMS).	MR
3	Compartmentation.	Required	Provided	
	• Fire check door	-----	-----	-----
	• Sealing of electrical shafts	-----	-----	-----
	• Fire rating of shaft door	-----	-----	-----
	• Water curtain	-----	-----	-----
	• Fire Dampers	-----	-----	-----
4	Smoke Management System.			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5.	Fire Extinguisher			
	• Total numbers	03no.	05 No.	MR
	• types	ABC & Co2	ABC & Co2	MR



	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	1no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & smoke	Provided	MR
	• Location of main panel	Control Room	1 <sup>st</sup> basement	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooters's location	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	• basement	-----	-----	-----
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1 no.	1 no.	MR
	• Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	Not Required	1no.	MR
	• Hose Box	Not Required	1 no.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850 LPM	2850 LPM	MR
	➤ Head of Main Pump	60 Mtrs.	60 mtrs	MR
	➤ Number of main pumps	1 nos.	1 nos.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	60 Mtrs.	60 mtrs.	MR
	➤ Standby pump out put	2850 LPM	2850 LPM	MR
	➤ Standby pump Head	60 Mtrs	60 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Auto	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	.....	.....	.....
	➤ Head of the Pump	.....	.....	.....
	➤ Power supply	.....	.....	.....
	➤ Auto Starting of pump	.....	.....	.....
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR

	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30000 Ltrs.	30000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	Required	1000 KVA	MR
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	----do----	MR
	• PA system panel	Required	----do-----	MR
	• Batter backup	Required	----do----	MR
	• Building Floor Plans	Required	----do---	MR
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Gurmukh Singh*  
27/1/12  
Signature of the Inspecting Officer

Name GURMUKH SINGH

Designation ADD(EN)

DO(E)

Submitted for approval please.

CPD

*Mugh*  
5/1/12