

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2011/EH/2493

Dated:- 10/07/12

FIRE SAFETY CERTIFICATE

Certified that the *Moti Mahal Delux Pandoori Trail at GA-7 & 8;*
Unitech Metro Walk located at *sector-10 Rohini Delhi (A unit of*
Duck Retail.) comprised of *Ground floor only* occupied
by *Moti Mahal Delux Pandoori Trail* was issued NOC vide this office letter
No. *F.6/DFS/MS/EH/09/1108* Dated: *23/4/2009* The premises was re-inspected by the
officer concerned of this department on *23/6/12* and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Assembly with effect from *10/07/12* for a period of
3 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *10/07/12* at New Delhi.

Note:-Guidelines overleaf may also be taken care of.

[Signature]
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *Sh. Sandeep Sethi*
Moti Mahal Delux Pandoori Trail
(A unit of Duck Retail.)
GA-7 & 8 Unitech Metro Walk
Sec - 10 Rohini Delhi

2.
.....
.....
.....

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Mel Mahal Deluxe Tandora Tsail, GA-748, Vitech metro walk, Sec-10, Rohini, Delhi
2. Type of Occupancy : Restaurant (Assembly Bldg) at G.F.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FC/DFP/MS/EM/09/1008 Dated: 23.4.09
5. Fire Safety directives letter No : -
6. Date of inspection : 23.06.12
7. Name of the Inspecting Officers : DO Jipin Kental
8. Name and designation of officers from the building side : Mr Sethi
9. Year of Construction : 2006-07
10. Applicant's letter No. : -

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	4.5 mtr	P /	M/R
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		N/A	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	N/A	1.2 mtr x 1 mtr	NOC already issued by deppt.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N.A. Provided in kitchen.	NOC already issued
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 ABC type 1 water CO2 type ISI marked	P ABC & water CO2	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 m 5 mm	P P P	M/R " "
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	R	P	M/R
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	n/a	P	P
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		n/a	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		/	
13	Pumping Arrangements.		n/a	
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		/	
				Pumps common with metro walk.
				M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		n/a	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		water capture tanks	
			common when needed	
15	Exit Signage.		✓	M/R
16	Provision of Lifts.		✓	✓
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		NA	
17	Standby power supply		✓	M/R
18	Refuge Area.		✓	✓
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		NA	
19	Fire Control Room		✓	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		NA	
20	Special Fire Protection Systems for Protection of special Risks, if any:			—
			no such risk at present.	—

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Kental
Signature of the Inspecting C

Name *VIPIN KENTAL*

Designation *DD N. 4*