

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2012/ *school/2520*

Dated:- *13/07/12*

FIRE SAFETY CERTIFICATE

Certified that the *A-One International Public School, B-Block*
Under Enclave phase - I, Delhi - 110086 comprised of *Single block construction*
of Basement + Ground + one upper floor owned/occupied by *Daya Nand -*
Trust (Regd.) Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *24.5.2012* in the presence of
Mr. Sudeep K. S. and that the building/premises is fit for occupancy
Educational building with effect from *13/07/12* for a period of
3 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *13/07/12* at New Delhi.

[Signature]
Chief Fire Officer
Delhi Fire Service

Copy to:-

- The Principal*
A-One International Public School,
Under Enclave phase - I, Delhi - 86
- The Addl. Director of Edun. (BCT.)*
Old Sectt. Govt. of NCT of Delhi
Delhi - 54

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.


INSPECTION REPORT

- N/1
1. Name & address of the building A-One International^{Publ.} School, B-Block, Indler.
 2. Type of Occupancy Educational -Enclave, Delhi
 3. Type of Case New Case/ Renewal
 4. Details of previous NOC : Letter No. NIL Dated: _____
 5. Fire Safety directives letter No F-16/estate/cc/f.safety/11/3298-3398 dt. 13/11
 6. Date of inspection 24-5-2012
 7. Name of the Inspecting Officers : ADO - SHYAM LAL
 8. Name and designation of officers Principal - Suresh Pal.
from the building side
 9. Year of Construction 2010, (B+Gr.+1)
 10. Applicant's letter No. BLD:ICF011101 dated 2.5-2012.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular NBC Requirement 1/3/2011</u> Director of Edun.	Provided at site	Remarks M/R
1	Access to building			
	• Road width	<u>Accessible</u>	<u>12 m</u>	<u>M/R</u>
	• Gate width	<u>-do-</u>	<u>5 m</u>	<u>M/R</u>
	• Width of internal road	<u>-do-</u>	<u>6 m</u>	<u>M/R</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>4</u>	<u>4</u>	<u>M/R</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Basements	<u>2</u>	<u>2</u>	<u>M/R</u>
	b. Width of staircases	<u>1.5 m</u>	<u>1.5 m & 1.25 m</u>	<u>M/R</u>
	• Upper Floors	<u>1.5 m</u>	<u>-do-</u>	<u>M/R</u>
	• Basements	<u>1.5 m</u>	<u>-do-</u>	<u>M/R</u>
	c. Protection of exits			
	• Fire check door		<u>M/R</u>	
	• Pressurization			
	e. No. of continuous staircases to terrace	<u>2</u>	<u>2</u>	<u>M/R</u>
	g. Width of Corridor	<u>R</u>	<u>2.80 m</u>	<u>M/R</u>
	h. Door Size	<u>1 m</u>	<u>1.05 m</u>	<u>M/R</u>

M/V

				NIR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			NIR
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	300 ml covered area for one ABC or CO2 (2.5kg) ISI marked	6 A ABC yes	MIR MIR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NIR 30 m 5 mm	P-2 30 m 5 mm	MIR MIR MIR
7	Automatic fire detection and alarming system.			NIR
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			NIR
9	Public Address System.			NIR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	Provided	MIR



N/G

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NIR	
			NIR	
		10000 Ltrs.	10000 Ltrs.	MIR
15	Exit Signage.	NIR	provided	MIR
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		NIR	
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		NIR	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		Nil	

The fire protection systems provided in the building were test checked and found functional at t of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Submitted for approval for vent 4/7

D/o. N.P.

What about conditions on the safety certificate

vent 28/5 fresh performance enclosed please

D.O. 28/5/12

29/5

Shylal 25/5/2012 (SHYAM LAL) Assit. Divn. officer