

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/school/2549

Dated:- 16/07/12

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarodaya Kanya Vidyalaya Badli
Delhi comprised of Ground + first floor (New Bldg.)
and Ground + first & second floor (Old Bldg.) owned/occupied by Govt. Sarodaya
Kanya Vidyalaya Delhi Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on 26/6/12 in the presence of
Principal and that the building/premises is fit for occupancy
Educational building with effect from 16/07/12 for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 16/07/12 at New Delhi.

Copy to:-

1. The Principal
Govt. Sarodaya Kanya Vidyalaya
Badli Delhi

2. The Project Director (Edn.)
DSIDE Ltd.
Technical Centre Bldg.
Wazirpur Ind. Area Delhi 110052

Ref. letter no. DSIDE/PPD (Edn.)/2011-12/1054 dt-28/4/12

Note:- This fire safety certificate is subject to compliance of the condition printed over leaf.

13/7
Chief Fire Officer
Delhi Fire Service
JK

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked		
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30 m 5 mm	P P P	Short circuit completed. " "
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 				
		R	P		
		10,000 lit	P		Short coming compliance
15	Exit Signage.				
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 				
17	Standby power supply				
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 				
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 				
20	Special Fire Protection Systems for Protection of special Risks, if any:				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Govt. Samadhyakaya Vidyalaya
Bedli Palu

Signature of the Inspecting Officer

Kentat
27/11/12
Signature of the Inspecting C

Name

Name *VIPIN KENTAT*

Designation

Designation *DO, Palu*