

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/SH/2012/2544

Dated: 16 /07 /2012

FIRE SAFETY CERTIFICATE

Certified that the **Vishesh Continental (Guest House)** located at F-35, Central Mkt, Kirti Nagar, New Delhi-110015, comprised of ground floor, first floor (11 rooms), Second floor (11 rooms) & Third floor (11 rooms) only, was granted NOC by this department vide letter No. **F6/DFS/MS/(EH)/08/927 dated 02/04/2008**. The premises was re-inspected by the officers concerned of this department on **14/06/2012** in the presence of **Smt. Seema Devi (Manager)** of the Guest House and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-A-1 (i) Residential** occupancy with effect from 16/07/12..... for a period of three years subject to conditions printed overleaf.

Issued on...16/07/12.....at New Delhi by


13/2
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police (Licensing)
First floor, PS Defence Colony, Delhi
2. **Smt. Seema Devi (Manager)**
Vishesh Continental (Guest House)
F-35, Central Mkt, Kirti Nagar, New Delhi-110015

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. 28563/Addl.C.P.(H) dated 14/05-2012 received from Addl. Commissioner of Police regarding renewal of NOC in r/o Vishesh Continental (Guest House) located at F35, Central Mkt, Kirti Nagar. Accordingly premises was inspected & observed that the comprised of ground floor, first floor, Second floor & Third floor only. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : Vishesh Continental (Guest House) located at F-35, Central Mkt, Kirti Nagar, New Delhi-110015
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/(EH)/08/927 dated 02/04/2008
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 14.06.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Smt. Seema Devi (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated 03.06.2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Old case	4.5 mtr & 9 mtr ✓	M/R being old Case ✓
	• Gate width	1.25 mtr	1.25 mtr ✓	M/R ✓
	• Width of internal road	NA.	N.A	Not applicable ✓
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Old case	01 ✓	M.R. old case ✓
	• Upper Floors	Old case	01 ✓	M.R. ✓
	• Basement	N/A	N/A	N/A

b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basement c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door size	Old case	1.25 mtr Provided ✓	M/R Renewal Case ✓
	Old case	1.25 & 1.17 mtr ✓	M.R. ✓
	N/A	N/A	N/A
	N.R.	N.R. ✓	N.R. ✓
	N.R.	N.R.	N.R.
	N.R.	N.R. ✓	N.R. ✓
	Old case	115, 145, 125 cm ✓	M.R. ✓
	Old case	1.25 mtr ✓	M.R. ✓
	3. Compartmentation.		
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.R.	N.R. ✓	N.R.
	N.R.	N.R.	N.R. ✓
	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
4. Smoke Management System.			
<ul style="list-style-type: none"> • Basements • Upper floors 	N.R.	N.R.	N.R.
	N.R.	N.R.	N.R.
5. Fire Extinguishers			
• Total numbers	10	15	M.R.
• Types	Required	provided	✓ M.R. ✓

	<ul style="list-style-type: none"> IS marking 	ISI marks Required	provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	provided	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m Required	provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm Required	provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Location of Main Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Alternate source of power 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Hooter's Location 	N.R.	N.R.	N.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N/R	N/R	N/R
	<ul style="list-style-type: none"> Upper Floor 	N/R	N/R	N/R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/R	N/R	N/R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 m	Provided	M.R.
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	M.R.

	• Hose Box	1	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	Not applicable
	• Hose Box	N.R.	N.R.	Not applicable
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	60 mtr	Provided	M.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	60 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			

	Underground tank capacity			
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	N.R.	N.P.	N.R.
	➤ Overhead Tank Capacity	Old case	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	Not applicable

	➤ Flow Switch Panel	N.R.	N.R.	Not applicable
	➤ PA system Panel	N.R.	N.R.	Not applicable
	➤ Batter backup	N.R.	N.R.	Not applicable
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

A O O Com M/Pestl.

Signature of the Inspection Officer

Name

Name

Designation

AM
Spini l chawdhary (D.O.W)

Designation