

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 2611

Dated : 19/07/12

FIRE SAFETY CERTIFICATE

Certified that the **Akasaka Restaurant** located at **28,Defence Colony Market, New Delhi-110024**.comprised of **Basement, Ground + 2 Upper Floor but the Restaurant is running on ground + 2 Upper Floor only** was granted NOC by this department vide letter No.F6/MS/DFS/EH/2009/1868 dated **25/06/09** The premises was re-inspected by the officer concerned of this department on **10/07/12** in the presence of **Mr. Pawan Bir Singh** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – D Assembly Building** with effect from---19/07/12---for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule-40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 19/07/12 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Dy. Health Officer,
South Zone, MCD, New Delhi.

(2) Akasaka Restaurant,
28,Defence Colony Market,New Delhi-110024.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Akasaka Restaurant,,28,Defence Colony Market,New Delhi-110024.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/MS/DFS/EH/2009/1868 dated 25/06/09
5. Fire safety directives No.- No
6. Date of inspection:- 10/07/2012
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik
8. Name & designation of officer:- Mr. Pawan Bir Singh
From the building side:-
9. Year of construction:- 1989
10. Applicant's letter No:-Nil dated 22/06/12 Basement,Ground + 2 Upper Floor but the Restaurant is running on ground + 2 upper Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL as per old NOC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	4.5 mtr.	4.5 mtr. Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Old Case	4.2 mtr. 9 cms.	MR old case
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	one	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers		08 Nos.	MR

	2) Types	ISI Marked	ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	One at each floor	One at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	yes	provided	M/R
	2) Upper floors	Yes	Provided	MR
	3) Sprinkler above false ceiling	Yes	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	Yes	100 mm	MR
	2) Number of hydrants per floor	Yes	1 Nos.	MR
	3) Hose box	Yes	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM & 180 LPM	450 LPM & 180 LPM	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Yes	Provided	MR
	d) Auto starting of pump	Yes	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltrs.	2500 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer




Name

Designation


Doc South

Signature of the inspecting officer



Name:- S.S. Kaushik.

Designation:- Assistant Divisional Officer.



13/7/12