

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/GH/2012/ 26/5

Dated: 20/07/12

**FIRE SAFETY CERTIFICATE**

Certified that M/s Astoria Hotel located at 733, Church Mission road, Fatehpuri, Delhi comprised of ground floor (Reception + 02 guest rooms + 01 store), Mezzanine floor (01 store), first floor (13 guest rooms) and second floor (Owners residence) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/1067 dated 21-04-2009. The premises was re-inspected by the officer concerned of this department on 28-06-2012 in the presence of Mr. Inderpal Singh, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 20/07/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 20/07/12 at New Delhi by.

  
Chief Fire Officer  
Director  
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi
  2. The Manager, M/s Astoria Hotel, 733, Church Mission road, Fatehpuri, Delhi
- Conditions for the validity of fire safety certificate
- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
  - b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
  - c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
  - d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Hotel Astoria, 733, E.M. Road, Fatehpur, Delhi
2. Type of Occupancy : Lodging House
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/GH/09/1067 Dated: 24/4/2009
5. Fire Safety directives letter No : -
6. Date of inspection : 28/6/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO(HE)
8. Name and designation of officers from the building side : Sh. Indrapal Singh, Manager
9. Year of Construction : 1952
10. Applicant's letter No. : U1240-44 /Add.C.P/Lic(CHA) dtd 29/6/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	spl area	18mt	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	spl area	01	MR
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	spl area	1.25mt	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	Not required	-	-
	• Pressurization	Not applicable	-	-
	e. No. of continuous staircases to terrace	spl area	01	MR being old
	g. Width of Corridor	-	1.21mt	MR
	h. Door Size	-	0.91mt	MR
		-	-	-
3	<b>Compartmentation.</b>	Not required	-	-

GF - Reception + 02 Guest rooms + 01 Store  
 Mez floor - 01 store  
 1st floor - 13 Guest rooms  
 2nd floor - Owner's residence.

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>	Not required being old case.		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour		
		12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers 07</li> <li>• Types water CO<sub>2</sub>-3, CO<sub>2</sub>-4</li> <li>• IS marking</li> </ul>	water CO <sub>2</sub> -3 CO <sub>2</sub> -4 ISI marked	provided provided provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	1st floor 30 m 5 mm	provided provided provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	Not required	→	→
9	<b>Public Address System.</b>	Required	provided	MR
10	<b>Automatic Sprinkler System.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>	Not required		
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	→	→	→

*[Handwritten signature]*

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b> <i>Not required</i>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		225 LPM	225 LPM	MR
		—	30 mt	MR
			provided	MR
		—	Switch provided at GF reception	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
		2500 ltr	2500 ltr	MR
15	<b>Exit Signage.</b>	Required	provided	MR
16	<b>Provision of Lifts.</b> <i>Not applicable.</i>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	—	—	—

*[Signature]*

Aslona Hotel, 733, C.M. Road, Falchpuri, Delhi

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>	Required	provided	MR
18	<b>Refuge Area.</b>	Not required		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	<b>Fire Control Room</b>	Not required		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO <sub>2</sub> type fire extinguisher provided near 2 panel.	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~<sup>renew</sup> Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Name

Designation

DO (CO)   
9/7/12

Signature of the Inspecting Officer

Name M. K. CHATTO PADHYAY

Designation ADO (HQ)

