

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2012 / EH / 2569

Dated 18/07/12

FIRE SAFETY CERTIFICATE

Certified that the Ignish Restaurant located at B-45, (1st floor) Connaught Circus, New Delhi was granted NOC by this department vide letter No F6/MS/DFS/EH/2009/ 881 dated 27.03.2009. The premises was inspected by the officer concerned of this department on 05.07.2012 in the presence of Mr. Sabharwal and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from ...18/07/12... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ...18/07/12... at New Delhi by.


Chief Fire Officer
Delhi Fire Service


Copy to: -

1. The Medical Officer of Health, Health Department, Palika Kendra, NDMC, New Delhi-01
2. Ignish Restaurant located at B-45, (1st floor) Connaught Circus, New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/S Ignish Restaurant, B-45, 1st floor,
Connaught Circus, N D-1
2. Type of Occupancy: Restaurant
3. Type of Case: Old
4. Details of previous NOC: Letter No FC/OAS/MS/BH/2009/081 dated 27/09/09.
5. Fire Safety directives Letter No.: N/A
6. Date of inspection: 2/07/12
7. Name of the Inspecting Officer: ATULGARJE D.S. yadav.
8. Name and designation of Officer: MR Purohit
from the building side
9. Year of Construction: Before 1983
10. Applicant's letter No.: N/M/C
MOH/D/1207/CSIC(LC)SI-1 dated 5/6/12

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A		
	• Gate width	N/A		
	• Width of internal road	N/A		
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	Two	Two	MR
	• Upper floors	Two	Two	MR
	• Basements	N/A		
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A		
	c. Protection of exits	N/A		
	• Fire check door	N/A		
	• Pressurization	N/A		
	d. No of continuous staircase to terrace	N/A		

old case

	e. Width Of Corridor	N/A		
	f. Door Size	N/A		
3.	Compartmentation			
	• Fire check door	N/A		
	• Sealing of electrical shafts	N/A		
	• Fire Rating of shaft door	N/A		
	• Water Curtain	N/A		
	• Fire Dampers	N/A		
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	
	• Upper floors	12 a/c per hour	Ys	MR
5.	Fire Extinguishers			
	• Total numbers	6	6 (5H)	MR
	• Types	ISI marked	WT, CO2	MR
	• IS marking		Ys	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	002	002	MR
	• Length of hose reel hose	30	Ys	MR
	• Nozzle diameter	5mm	Ys	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A		
	• Location of Main Panel	N/A		
	• Location of Repeater Panel	N/A		
	• Alternate source of power	N/A		
	• Hooters' Location	N/A		
8.	MOEFA	YES	Ys	MR
9.	Public Address System	Ys	Ys	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	
	• Upper Floor	Ys	Ys	MR

	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A		
	• Number of hydrants per floor	N/A		
	• Hose Box	N/A		
12.	Yard Hydrants			
	• Total number of hydrants	N/A		
	• Hose Box	N/A		
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A		
	➤ Head of main pump	N/A		
	➤ Number of main pumps	N/A		
	➤ Jockey pump out put	N/A		
	➤ Jockey pump head	N/A		
	➤ Standby Pump out put	N/A		
	➤ Standby Pump Head	N/A		
	➤ Auto Starting/Manual stopping	N/A		
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	yes	M R
	➤ Head of the pump	30 m	yes	M R
	➤ Power supply	yes	yes	M R
	➤ Auto starting of pump	yes	yes	M R
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A		
	➤ Draw of connection	N/A		
	➤ Fire service inlet	yes	yes	M R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 Lt	yes	M R

15	Exit Signage	Ys	Ys	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A		
	➤ Pressurization of lift lobby	N/A		
	➤ Communication in lift Car	N/A		
	➤ Fireman's Grounding Switch	N/A		
	➤ Lift Signage	N/A		
17.	Standby power supply	Ys	Ys	MR
18.	Refuge Area			
	➤ Total area	N/A		
	➤ Location	N/A		
19.	Fire control room			
	➤ Detector system panel	N/A		
	➤ Flow Switch Panel	N/A		
	➤ PA System Panel	N/A		
	➤ Batter backup	N/A		
	➤ Building Floor Plans	N/A		
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]

[Handwritten Signature]

D. S. Yadav

A.D.O / C.C