

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001**

No.F6/DFS/MS/EH/2012/ 2607

Dated :- 19/07/12

**FIRE SAFETY CERTIFICATE**

Certified that the **KFC ( A Unit of Yum India Pvt. Ltd.)** located at **02B,select City Mall,Saket,New Delhi.** comprised of **Basement,Ground + 2 Upper Floor but the Restaurant is running on ground Floor only** was granted NOC by this department vide letter No.F6/DFS/MS/EH/2009/1574 dated **01/06/09** The premises was re-inspected by the officer concerned of this department on **03/07/12** in the presence of **Mr. Aman Deep** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – D Assembly Building** with effect from ~~19/07/12~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~19/07/12~~ at New Delhi by.

  
Chief Fire Officer  
Delhi Fire Service

- Copy to:- (1) Dy. Health Officer,  
South Zone, MCD, Green Park, New Delhi.
- (2) KFC (A Unit of Yum India Pvt. Ltd.),  
02B, Select City Mall, Saket, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:- KFC ( A Unit of Yum India Pvt. Ltd.),02B,select City Mall,Saket,New Delhi.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/MS/DFS/EH/2009/1574 dated 01/06/09
5. Fire safety directives No.- No
6. Date of inspection:- 03/07/12.
7. Name of the inspecting officer:-D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. Aman Deep.
9. Year of construction:- 2007.
10. Applicant's letter No:-Nil dated 24/06/12 Basement,Ground + 2 Upper Floor but the Restaurant is running on ground, Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	10 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	1.5 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	04 Nos.	MR
	2) Types		ABC	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			

- 4/5 -

	1) Total number of each floor	1 Nos.	Provided by mall	MR
	2) Length of hose reel hose	30 m	Provided by mall	MR
	3) Nozzle diameter	5 mm	Provided by mall	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Ground Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Battery Backup	MR
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	150 mm	Provided by mall	MR
	2) Number of hydrants per floor	Required	Provided by mall	MR
	3) Hose box	Required	Provided by mall	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	Required	Provided by mall	MR
	2) Hose box	Required	Provided by mall	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	4500 LPM	Provided by mall	MR
	b) Head of main pump	88 mtr.	Provided by mall	MR
	c) Number of main pump	Two	Provided by mall	MR
	d) Jockey pump out put	180 LPM	Provided by mall	MR
	e) Jockey pump head	88 mtr.	Provided by mall	MR
	f) Stand by pump output	4500 LPM	Provided by mall	MR
	g) Stand by pump head	88 mtr.	Provided by mall	MR
	h) Auto starting/Manual stopping	Required	Provided (both)	MR
	2) Terrace level			
	a) Discharge of pump	180 LPM	Provided by mall	MR
	b) Head of pump	40 mtr.	Provided by mall	MR

- 11/6 -

	c) Power supply	Required	Provided by mall	MR
	d) Auto starting of pump	Required	Provided by mall	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	5,00,000 Ltrs.	Provided by mall	MR
	a) Draw-off connection	Required	Provided by mall	MR
	b) Fire service inlet	Required	Provided by mall	MR
	c) Access to tank	Required	Provided by mall	MR
	d) Over head tank capacity	30,000 Ltrs.	Provided by mall	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided	MR
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj

Name:- S.S. Kaushik.

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer.