

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/ *School / 2620*

Dated:- *20/07/12*

FIRE SAFETY CERTIFICATE

Certified that the *G.D. Goenka Public school (formerly known as Rosewood Public School & Kings Valley School)* located at *Sector-9 Rohini Delhi* comprised of *Ground + 3 upper floors* occupied by *G.D. Goenka Public School* was issued NOC vide this office letter No. *F-6/DFS/MS/2005/2436* Dated: *29/11/05*. The premises was re-inspected by the officer concerned of this department on *19/6/12* and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class *Educational* with effect from *20/07/12* for a period of *03 years* in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *20/07/12* at New Delhi.

Note:-Guidelines overleaf may also be taken care of.

Copy to:-

1. *Ms. Anita Rana (Manager)*
G.D. Goenka Public School
Sect-9
Rohini Delhi

2.
.....
.....
.....

[Signature]
Chief Fire Officer
Delhi Fire Service

[Signature]

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

G.D. Goenka Public School, Sec - 9, Rohini, Delhi formerly known as Rosewood Public School.

1. Name & address of the building : _____
2. Type of Occupancy : School (Education Bldg)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. FE/DFS/MS/2005/2436 Dated: 29.11.05
5. Fire Safety directives letter No : FE/DFS/MS/SP/2003/3162 dt- 29.12.03
6. Date of inspection : 14.6.12
7. Name of the Inspecting Officers : Do Vipin Kantal.
8. Name and designation of officers from the building side : Mr. Varun.
9. Year of Construction : 2005
10. Applicant's letter No. : may 15 2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	-	-	-
	• Gate width	5mtr	P	M/R
	• Width of internal road	N/A	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	M/R
	• Basements	N/A	-	-
	b. Width of staircases			
	• Upper Floors	-	(i) 142 cm (ii) 143 cm.	NOC already issued by dept.
	• Basements	N/A	-	-
	c. Protection of exits			
	• Fire check door	N/A	/	
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	100 cm.	100cm with door frame	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	natural ventilation on relief by providing operable windows in A.C shafts	M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 on every floor. Two water Co2 Two CO2/ABC ISI marked type 2 kg each	P	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30 m 5 mm	P " "	M/R " "
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8	MOEFA			
			N/A	
9	Public Address System.			
		R	P	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 		N/A	

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	P	MIR
		2	P	MIR
		2	P	MIR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A		
		900 LPM	P	MIR
		220 LPM		
		R	P	MIR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	50,000 ltr	P cap not known	Tank not required as per new norms

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	10,000. h/h	P	M/R
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply	R	P	M/R
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:			no such risk at present

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Kentel
Signature of the Inspecting Offi

Name *VIPIN KENTAL*

Designation *DO, N.W.*