

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2012/ *school/2632*

Dated: *20/07/12*

FIRE SAFETY CERTIFICATE

Certified that the – **Govt. Sarvodaya Bal Vidyalaya, West Patel Nagar, New Delhi-110008** comprised of - ground floor plus two upper floors, owned/occupied by Director of Education Govt. of N.C. T. of Delhi has complied with the fire prevention and fire safety requirements in accordance with the National Building Code-IV -2005 and verified by the officer concerned of fire Service on 04.07.12 in the presence of Dr. Vir Singh, Principal, and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on ...*20/07/12*.....at New Delhi.


Chief Fire Service
Delhi Fire Service
o/c

Copy to:

1. The Principal,
Govt. Sarvodaya Bal Vidyalaya,
West Patel Nagar,
New Delhi-110008.
2. The Director of Education
Govt. of N.C.T. of Delhi,
Old secretariat, Delhi.
3. Divisional Officer (South West) SRD.

Note * :- For general fire safety directives please see overleaf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the responsibility of the management.
3. The staff should be trained available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

G+2

INSPECTION REPORT

- 1. Name & address of the building : Gmt Sarvodaya Bal Vidyalaya West Patil Ngr
- 2. Type of Occupancy : Educational N. D
- 3. Type of Case : New Case/ ~~Renewal~~
- 4. Details of previous NOC : Letter No. NIL Dated: _____
- 5. Fire Safety directives letter No : F. 6 / DFE / Ms / 2012 / Seh / 1105 dt 27/3/12
- 6. Date of inspection : 04/07/12
- 7. Name of the Inspecting Officers : H.L. ANEJA Dir. Officer.
- 8. Name and designation of officers from the building side : DR VIR SINGH Principal
- 9. Year of Construction : —
- 10. Applicant's letter No. : G.S.B.V. / WPN / 489 dt 20.6.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	13 mtr ✓	MR
	• Gate width	R	3.7 mtr ✓	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	— ✓	—
	• Basements	NIL	—	—
	b. Width of staircases	R	i) 160cms ii) 152cms ✓	MR
	• Upper Floors	—	— ✓	—
	• Basements	NIL	—	—
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos ✓	—
	g. Width of Corridor		212cms	
	h. Door Size	R	210 X 105cms	MR

3	Compartmentation.	NR		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.	NR		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers	R	P	MR
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	16 Nos AB type Yes	MR -u- -u-
6	First-Aid Hose Reels.	R	P	MR
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	6 Nos Provided	MR -u- -u-
7	Automatic fire detection and alarming system.	NR		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NR		
9	Public Address System.	NR		
10	Automatic Sprinkler System.	NR		
	<ul style="list-style-type: none"> • Basement 			

7	➤ Fire service inlet	R	Provided	MR
	➤ Access to tank		Provided	MR
	• Overhead Tank capacity	R	10000 ltr	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.	NR	NP	-
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	NR	-	-
18	Refuge Area.	NR	-	-
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room	NR	-	-
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PAI System Panel	-	-	-
	• Batter backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... Nil.....

Govt Sansodya Vidyalaya West Patel Nagar



Signature of the Inspecting Officer

Name H. L. ANETA

Designation Dir. Officers

Signature of the Inspecting Officer

Name

Designation