

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.


No. F.6/DFS/MS/GH/2012/ 2627

Dated: 20/07/12

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Shaleen**, located at 4/37, WEA, Krishna Market, Karol Bagh, New Delhi-110005 comprised of Ground Floor plus two upper floors, using ground floor as reception & four guest rooms, first floor having five guest rooms, second floor having two guest rooms (Total Eleven guest rooms). Above guest house was issued NOC vide this office letter No.F.6/DFS/MS/GH/2008/3192 dated 19/11/2008 owned/occupied by Sh. Ved Prakash Taneja have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 14.07.2012 in the presence of Sh. Ved Prakash Taneja (Owner). The building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....20/07/12..... at New Delhi.

  
187  
CHIEF FIRE OFFICER  
For DIRECTOR  
DELHI FIRE SERVICE  
etc

Copy to:-

1. The Addl. Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Re. No.41684/Addl. C.P./Lic.(H), Dated 29.06.2012)
2. Mr. Ved Prakash Taneja(Owner)  
Hotel Shaleen,  
4/37, WEA, Krishna Mkt.,  
Karol Bagh, New Delhi – 05.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Ground Floor plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : Hotel Shaleen, 4/37, WEA, Krishnamkt, Karol Bagh, No. 05.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/08/3192 Date 19.11.2008
5. Fire Safety directives letter No : NIA
6. Date of inspection : 14.07.2012
7. Name of Inspecting Officer : D.O.H.L. Anjia & A.D.O. P.S. Dahiya
8. Name and designation of officers  
From the building side : Sh. Ved Prakash Taneja (Owner)
9. Year of Construction : Before 2001
10. Applicant's letter No. : 41684/Addl. C.P/Lic.(H) dated 29.06.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	06 mtr	MR
	• Gate width	-	200 cmp	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	-	125 cmp	MR, Being Old Case
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	NIA	-	-
	• pressurization	NIA	-	-
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	85 cmp, 250 cmp	-
	f. Door Size	-	76 cmp x 202 cmp	-
3.	Compartmentation			
	• Fire check door	NIA	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	NIA	-	-
	• Water Curtain	NIA	-	-
	• Fire Dampers	NIA	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each floor	Provided	MR
	• Types	CO <sub>2</sub> , WCO <sub>2</sub>	- do -	MR
	• IS marking	ISI marked	- do -	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	-	D.G. Set 115KVA	-
	• Hooters' Location	-	-	-
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	-	-
	• Number of hydrants per floor	N/A	-	-
	• Hose Box	N/A	-	-
12.	Yard Hydrants			
	• Total number of hydrants	N/A	-	-
	• Hose Box	N/A	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-
		N/A	-	-


4/37, WEA, Krishna MKT,  
Kharol Bagh, New Delhi-05.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	N/A	-	-
		N/A	220 LPM	MR
		N/A	30 M	MR
		Required	Provided	MR
		-	-	-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		MR	2500 Ltr	MR, Total 11 Guest Rooms
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	NO Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	<b>Standby power supply</b>	Required	Provided	MR.
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	-	-
		N/A	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to <sup>Renewal</sup> grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~


Note:- The Guest house building having eleven Guest rooms, no basement hence Only First Aid Fire Extinguishers are required as per NBC Part IV.



Signature of Inspecting Officer

Name H.L. Aneja

Designation Divisional Officer



Signature of Inspecting Officer

Name P.S. Dahiya

Designation ABPH. Divisional Officer.