

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/Cinema/2012/2630

Dated: 20/07/2012

FIRE SAFETY CERTIFICATE

Certified that the **M2K Entertainment Pvt. Ltd.**, Plot no. 4, road no. 44, Community Center Pitampura, New Delhi-110034, comprised of lower basement, upper basement & ground plus third floor only, was granted NOC by this department vide letter No. **F6/DFS/MS/2005/1159 dated 11/07/2005**. The premises was re-inspected by the officers concerned of this department on **22/06/2012** in the presence of **Sh. Kaul** of the M2K Mall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-F (Mercantile)** occupancy with effect from 20/07/12 for a period of three years subject to conditions printed overleaf.

Issued on...20/07/12.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:
Sh. Kaul
M2K Entertainment Pvt. Ltd.,
Plot no. 4, road no. 44, Community Center Pitampura,
New Delhi-110034

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 17-05-2012 received from Authorised Signatory (M2K) regarding issue of NOC in favor of their **M2K Entertainment Pvt. Ltd.**, Plot no. 4, road no. 44, Community Center Pitampura, New Delhi-110034. Accordingly premises was inspected & observed that the building comprised of lower basement, upper basement & ground plus three upper floors only. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **M2K Entertainment Pvt. Ltd.**, Plot no. 4, road no. 44, Community Center Pitampura, New Delhi-110034.
2. Type of Occupancy : Class -F (Mercantile)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2005/1159 dated 11/07/2005
5. Fire Safety directives letter No. : F6/MS/DFS/ 2005/1271 dated 14/06/2005
6. Date of inspection : 22.06.2012
7. Name of the Inspecting Officers : A.D.O. Rajmal Khokhar & D.O. Sunil Chawdhary
8. Name and designation of officers
 From the building side : Sh. Kaul
9. Year of Construction :
10. Applicant's letter No. : nil dated 17-05-2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	24 mtr ✓	M/R
	• Gate width	5 mtr	Provided ✓	M/R
	• Width of internal road	Old case	Old case ✓	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	3	Provided ✓	M.R

	<ul style="list-style-type: none"> Basement 	2	Provided ✓	M.R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	1.25 mtrs	Provided ✓	M.R.
	<ul style="list-style-type: none"> Basement 	1.25 mtr	Provided ✓	M.R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	M.R
	<ul style="list-style-type: none"> Pressurization 	Required	Provided ✓	M.R
	d. No. of continuous staircases to terrace	3	provided ✓	M.R
	e. Width of Corridor	Old case	Old case ✓	Being old case M.R
	f. Door size	Old	Old case ✓	Being old case M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	M.R
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided ✓	M.R
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided ✓	M.R
	<ul style="list-style-type: none"> Water Curtain 	Required	Provided ✓	M.R
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided ✓	M.R
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper floors 	Required	Provided ✓	M.R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	22	35 ✓	M.R

	<ul style="list-style-type: none"> Types 	required	provided	M.R
	<ul style="list-style-type: none"> IS marking 	required	provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	2, Old case	Provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	Provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	M.R
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System.	Required	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm old case	Provided	M.R

	<ul style="list-style-type: none"> Number of hydrants per floor 	2, Old case	Provided ✓	M.R.
	<ul style="list-style-type: none"> Hose Box 	2, Old case	Provided ✓	M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Hose Box 	Required	Provided ✓	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2850 LPM	Provided ✓	M.R.
	➤ Head of Main pump	60 mtr	Provided ✓	M.R.
	➤ Number of main pumps	2	Provided ✓	M.R.
	➤ Jockey Pump out put	180 LPM	Provided ✓	M.R.
	➤ Jockey pump head	60 mtr	Provided ✓	M.R.
	➤ Standby pump out put	2850 LPM	Provided ✓	M.R.
	➤ Standby pump Head	60 mtr	Provided ✓	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided ✓	M.R.
	➤ Pump Hose Access	Required	Provided ✓	M.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided ✓	M.R.
	➤ Head of the pump	50 mtr	Provided ✓	M.R.
	➤ Power supply	Required	Provided ✓	M.R.

	➤ Auto Starting of pump	N.R.	N.P.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1 lakh ltrs	provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	Required 20,000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	M.R.
	• Pressurization of Lift lobby	Required	Provided	M.R.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R.
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area	Required	Provided	M.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R.

	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


Signature of the Inspection Officer

Signature of the Inspection Officer

Name RAJMAL KHOKHAR

Name

Designation ASD

Designation

20/05/15
DA-Speak M