

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2012/ EH/2635

Dated:- 20/07/12

FIRE SAFETY CERTIFICATE

Certified that the M/s PIZZA HUT Restaurant (A Unit of Deryani International Pvt.)
Chp no- 9) Pn-17 Sec-3 Rohini located at Manglam Palace Rohini Delhi
..... comprised of Ground floor occupied
by Pizza Hut (A Unit of Deryani Int. Pvt.) was issued NOC vide this office letter
No. F 6/MS/DFS/MS/2012/2608/2012 Dated: 6/11/08 The premises was re-inspected by the
officer concerned of this department on 11/7/12 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Assembly with effect from 20/07/12 for a period of
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 20/07/12 at New Delhi.

Note:-Guidelines overleaf may also be taken care of.

Copy to:-

1. The Dy Health Officer (MCD)
Health Deptt.
Rohini zone
Sec-5, Rohini Delhi
2. The Chief of operation
M/s Deryani International Pvt.
F-2/7 Okhla Ind. Area.
Ph-1 New Delhi

19/12
Chief Fire Officer
Delhi Fire Service

92

✓

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/12

To verify the Compliance of short comings

INSPECTION REPORT

1. Name & address of the building : PIZZA HUT Shop no. 9, Manglam Place, Plot No. 17, sec-3, Rohini, N. Delhi.
2. Type of Occupancy : Restaurant (Assembly hall)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F6/MS/DFS/EH/2008/3022 Dated: 4/11/08
5. Fire Safety directives letter No : -
6. Date of inspection : 11.7.12
7. Name of the Inspecting Officers : D.O upin kental
8. Name and designation of officers from the building side : D.O upin manager, PIZZA HUT.
9. Year of Construction : -
10. Applicant's letter No. : PIZZA HUT letter dt 5/7/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 			<u>Already mentioned in previous inspection report.</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			<u>/</u>
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			

10/19

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked		
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 m 5 mm	provided M/R (compliance made)	"
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

N/16

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

10/17

Signature of the Inspecting Officer

Ventur
Signature of the Inspecting Offi

Name

Name *VIPIN KENTAR*

Designation

Designation *DO, NVA*

The compliance of short coming at Sr.No. 6 (ie provision of h:seed) has been made.

V
11/7