

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F6/DFS/MS/EH/2012/2638

Dated: 20/07/2012

FIRE SAFETY CERTIFICATE

Certified that the **United Catering Services (A unit of Divya Restaurants & Hotels Pvt. Ltd)** located at B-93, Maya Puri, Phase-I, New Delhi. The building comprised of basement, ground floor plus three upper floors. The Fire Safety Certificate for basement & ground floor only. The basement used as storage and ground floor used as Kitchen only owned/ occupied by Sh. Akash Kalra (Director) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 23.06.2012 in the presence of Sh Sanjay Kumar and that the building/ premises is fit for occupancy class Group G Industrial building Sub- Division G-2 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....20/07/2012..... at New Delhi.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Deputy Health Officer,
Municipal Corporation of Delhi,
West Zone, Rajouri Garden, N.D-27.
(Ref. No. D-346/HD/WZ dated 13.03.12)
2. The Director,
Divya Restaurants & Hotel Pvt. Ltd.
B-93, Maya Puri, Phase-I, New Delhi.

pc
Mew

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Basement, Ground plus 2 1/2 upper floors.

INSPECTION REPORT

1. Name & address of the building : United Catering Services (A Unit of Darya Rest. & Hotels P. Ltd
2. Type of Occupancy : Group G, Sub Div - G-2, B-93, Maya Park, Phase - I, And
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date
5. Fire Safety directives letter No : F.6/DFS/ms/BP/89/1631 dated 14.08.89
6. Date of inspection : 23.06.2012
7. Name of Inspecting Officer : D.O H.L. Aneya & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Sanjay Kumar
9. Year of Construction : Before 2005
10. Applicant's letter No. : Nil dated 18.05.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	18mtr	MR
	• Gate width	-	03mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Two	MR
	• Upper Floors	- do -	- do -	MR
	• Basements	- do -	- do -	MR
	b. Width of staircases			
	• Upper Floor	-	125cm, 75cm	MR, Kitchen only at Ground floor.
	• Basements	-	200cm, 90cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace	-	Two	-
	e. Width of Corridor	-	-	-
	f. Door Size	-	-	-
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fans are provided	MR
	• Upper floors		Natural Ventilation	MR

		12 a/c per hour	←	—
5.	Fire Extinguishers			
	• Total numbers	Four at each floor	Provided	MR
	• Types	CO ₂ , ABC	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Smoke/Heat	MR
	• Location of Main Panel	—	At main Gate	MR
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	D.G Set of 62.5 kva	—
	• Hooters' Location	—	—	—
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor (Ground Floor)	- do -	- do -	MR
	• Sprinkler above false ceiling	N/A	—	—
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	—	—
	• Number of hydrants per floor	N/A	—	—
	• Hose Box	N/A	—	—
12.	Yard Hydrants			
	• Total number of hydrants	N/A	—	—
	• Hose Box	N/A	—	—
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	—	—
	➤ Head of Main pump	N/A	—	—
	➤ Number of main pumps	N/A	—	—
	➤ Jockey Pump out put	N/A	—	—
	➤ Jockey pump head	N/A	—	—
	➤ Standby Pump out put	N/A	—	—
	➤ Standby Pump Head	N/A	—	—
	➤ Auto Starting/Manual stopping	N/A	—	—
		N/A	—	—

B-93, Maya Puri, Phase-I,
New Delhi.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		900 LPM	900 LPM, 220 LPM	MR
		30M Required	30M Each Provided	MR MR
		-	Both	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	Provided	MR
		N/A	-	-
		10000 ltr	10000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	-	-
		N/A	-	-
		N/A	Provided	MR
		-	-	Old Lift
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The building comprised of Basement, Ground floor plus 2 1/2 upper floors on a plot area 140 sq.m approx. The kitchen run only at Ground floor having two exits of 300 cms and 140 cms width respectively. The basement used as storage and served by two exits of 200 cms and 90 cms width respectively. Exhaust fans are provided in the basement and Exhaust ducts are provided at Ground floor. The Fire Safety Certificate recommended for basement and Ground floor only.


Signature of Inspecting Officer

Name H.L. Anuja

Designation Divisional Officer


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asst. Divisional Officer.