

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/*school/2012/2666*

Dated: *23/07/12*

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Co-ed. School, Kilokri Tank, New Delhi**, comprised of ground plus one upper floor only **Owned/Occupied** by M.C. Primary Co-ed. School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 16.05.2012 in the presence of Miss/Mrs. Seema, Principal of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from *23/07/12* for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *23/07/12* at New Delhi by


23/
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
23/

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Principal, MC Primary Co-ed. School, Kilokri Tank, New Delhi-24

Conditions for the validity of fire safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : M.C Primary co-ed School
Kilokari Village, New Delhi
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : NEW Dated
5. Fire Safety Directives letter No : NEW
6. Date of Inspection : 16.05.2012
7. Name of the Inspecting Officer : Rajan Wadhera, ADO/MDA
8. Name and designation of the Officers from the building side : Miss/mr Seema, Principal
9. Year of Construction : (Ground plus one upper floor)
10. Applicant's letter No. :

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	15 MB	15 MB	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase			
	➤ Upper floors	Two	Two	M/R
	➤ Basement	NA	NA	NA
	• Width of Staircase			
	➤ Upper floors	1.5 MB	1.5 MB each	M/R
	➤ Basement	NA	NA	NA
	• Protection of Exits		NA	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size	NA	NA	NA

3	Compartmentation		NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 		
4	Smoke Management System		NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour 12 a/c Per hour	
5	Fire Extinguishers		
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	<u>01</u> /300 m ² ISI mark	
6	First-Aid Hose Reels		NA
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	<u> </u> /Per Floor 30 m 5mm	
7	Automatic Fire Detection and Alarming System		NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 		
8	MOEFA		NA
9	Public Address System		NA
10	Automatic Sprinkler System		NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		
11	Internal Hydrant		NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 		
12	Yard Hydrant		NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 		


13	Pumping Arrangements			
	Ground Level		NA	
	➤ Number of main pump			
	➤ Discharge of main pump			
	➤ Head of main pump			
	➤ Jockey pump out put			
	➤ Jockey pump Head			
	➤ Standby pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	Terrace level		NA	
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto starting /Manual stopping			
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead tank capacity			
15	Exit Signage		NA	
16	Provision of Lifts		NA	
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply		NA	
18	Refuge Area		NA	
	• Total Area			
	• Location			
19	Fire Control Room		NA	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			


20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number.....

DO (South)


28/5/12


Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER