

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2012 / GH/2708

Dated 24/07/12

FIRE SAFETY CERTIFICATE

Certified that the "Mini Yes Please" Guest House, located at 2026/7, Rajguru Road, Chuna Mandi, Pahar Ganj, New Delhi, comprised of Basement + Ground + Four upper floors having 14 guest rooms (Basement is vacant, Ground floor has Reception + 01 guest room, First to Third floor has 04 guest rooms at each floor, Fourth floor has 01 guest rooms + 01 staff Kitchen found sealed) was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2009/ 2011 dated 07.07.2009. The premise was re-inspected by the officer concerned of this department on 16.07.2012 in the presence of Mr. Vinod found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 24/07/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/07/12 at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Owner, "Mini Yes Please" Guest House, located at 2026/7, Rajguru Road, Chuna Mandi, Pahar Ganj, New Delhi.
2. The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. This NOC is for Guest Rooms only.

old case
SPL area

INSPECTION REPORT

1. Name & address of the building: M/S Mini yes plege, 2026/7, Chura mandi
Daharganj, Delhi
2. Type of Occupancy: Residential (Guesthouse)
3. Type of Case: old (Renewal)
4. Details of previous NOC: Letter No. FC/OFS/MS/GH/2009/2011 dated 7/07/09
5. Fire Safety directives Letter No.: N/A
6. Date of inspection: 16/07/12
7. Name of the Inspecting Officer: ADO/yadav
8. Name and designation of Officer: Mr Vinod
from the building side
9. Year of Construction: Before 2007 (AS/ON Renew)
10. Applicant's letter No.: ADICP 37743/ADDCP/LIC(H) dtd 6/6/12

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	6 Mtr	MR
	• Gate width	N/A		
	• Width of internal road	N/A		
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	one	one	MR
	• Upper floors	one	one	MR
	• Basements	one	one	MR
	b. Width of staircases			
	• Upper floors	0.90m	0.90m	MR
	• Basements	0.90m	0.90m	MR
	c. Protection of exits			
	• Fire check door	N/A		
	• Pressurization	N/A		
	d. No of continuous staircase to terrace	one	one	MR

	e. Width Of Corridor	N/A		
	f. Door Size	N/A		
3.	Compartmentation			
	• Fire check door	N/A		
	• Sealing of electrical shafts	N/A		
	• Fire Rating of shaft door	N/A		
	• Water Curtain	N/A		
	• Fire Dampers	N/A		
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	
	• Upper floors	12 a/c per hour	N/A	
5.	Fire Extinguishers			
	• Total numbers	12	12 (Tusler)	MR
	• Types	ISI marked	WT, CO ₂	MR
	• IS marking		Yes	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	one	Yes	MR
	• Length of hose reel hose	30 mts	Yes	MR
	• Nozzle diameter	5 mm	Yes	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A		
	• Location of Main Panel	N/A		
	• Location of Repeater Panel	N/A		
	• Alternate source of power	N/A		
	• Hooters' Location	N/A		
8.	MOEFA	Yes	Yes	MR
9.	Public Address System	Yes	Yes	MR
10.	Automatic Sprinkler System			
	• Basements	Yes	Yes	MR
	• Upper Floor	N/A	N/A	

	• Sprinkler above false ceiling	N/A		
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A		
	• Number of hydrants per floor	N/A		
	• Hose Box	N/A		
12.	Yard Hydrants			
	• Total number of hydrants	N/A		
	• Hose Box	N/A		
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A		
	➤ Head of main pump	N/A		
	➤ Number of main pumps	N/A		
	➤ Jockey pump out put	N/A		
	➤ Jockey pump head	N/A		
	➤ Standby Pump out put	N/A		
	➤ Standby Pump Head	N/A		
	➤ Auto Starting/Manual stopping	N/A		
	➤ Pump House Access	N/A		
	• Terrace level			
	➤ Discharge of pump	225 lps	YS	MR
	➤ Head of the pump	30m	YS	MR
	➤ Power supply	YS	YS	MR
	➤ Auto starting of pump	YS	YS	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A		
	➤ Draw of connection	N/A		
	➤ Fire service inlet	N/A		
	➤ Access to tank	N/A		
	• Overhead Tank capacity	5000L	YS	MR

15	Exit Signage	YB	YB	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A		
	➤ Pressurization of lift lobby	N/A		
	➤ Communication in lift Car	N/A		
	➤ Fireman's Grounding Switch	N/A		
	➤ Lift Signage	N/A		
17.	Standby power supply	YB	YB	MR
18.	Refuge Area			
	➤ Total area	N/A		
	➤ Location	N/A		
19.	Fire control room			
	➤ Detector system panel	N/A		
	➤ Flow Switch Panel	N/A		
	➤ PA System Panel	N/A		
	➤ Batter backup	N/A		
	➤ Building Floor Plans	N/A		
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation DD/CI

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation AD.O (C.C)