

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *FG/DPS/ms/school/2012/2680*

Dated: *24/07/12*

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Sarvodaya Bal Vidyalaya Gandhi Nagar (Opp. New Subzi Mandi, Jheel), Delhi-31, comprised of ground plus one upper floor owned/occupied by Rajkiya Sarvodaya Bal Vidyalaya Gandhi Nagar (Opp. New Subzi Mandi, Jheel), Delhi-31, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 09.07.12 in the presence of Dr. K.K. Madan, Principal of the school and that the building is fit for occupancy class B 'Educational Building' with effect from *24/07/12* for a period of three years, subject to conditions printed overleaf.

Issued on *24/07/12* at New Delhi by

[Signature]
23/7
Chief Fire Officer
Delhi Fire Service

To,

The Principal
Rajkiya Sarvodaya Bal Vidyalaya Gandhi Nagar
(Opp. New Subzi Mandi, Jheel), Delhi-31

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

[Signature]
20/7/12

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This F.S.C. may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

NRN-1

INSPECTION REPORT

1. Name & address of the building : Rajkiya Sarvodaya Bal Vidyalaya, Gandhi Nagar, (Opp. New Subzi Mandi, Jheel), Delhi-31
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of Previous NOC : Letter No- _____ Dated _____
5. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dt. 01.03.11
6. Date of Inspection : 09.07.12
7. Name of the Inspecting Officers : ADO Suresh singh
8. Name of the designation of Officer
 From the building side : Dr. K.K. Madan, Principal
9. Year of Construction : 2011-12
10. Applicant's letter No : RSBV/GN/12/344 dated 09.06.12

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	8 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	3 no.	MR
	Upper Floor
	Basement
	B. Width of Staircases	1.5 m	1.6 m each	MR
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
	g. Width of Corridor	1.7 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	N/A		
	• Fire check door
	• Sealing of electrical shafts
	• Fire rating of shaft door
	• Water curtain
	• Fire Dampers
4	Smoke Management System.	N/A		
	• Basement	30a/c per hour
	• Upper floor	12 a/c per hour

5.	Fire Extinguisher			
	<ul style="list-style-type: none"> Total numbers types IS marking 	10 no.	10 no.	MR
		Co2 & ABC	Co2 & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels. N/A			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter
		30 m
		5 mm
7	Automatic fire detection and alarming system. N/A			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooters's location
	
	
	
	
8	MOEFA	N/A
9	Public address System.	Yes
10	Automatic Sprinkler System. N/A			
	<ul style="list-style-type: none"> basement upper floor sprinkler above false ceiling
	
	
11	Internal Hydrants N/A			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose Box
	
	
12	Yard Hydrants. N/A			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box
	
13	Pumping Arrangements. N/A			
	<ul style="list-style-type: none"> ➤ Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main Pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump Head Auto Starting /Manual stopping Pump House Access ➤ Terrace Level <ul style="list-style-type: none"> .Discharge of pump Head of the Pump
	
	
	
	
	
	
	
	
	
	
	
	
	
	

	<ul style="list-style-type: none"> Power supply Auto Starting of pump
14	Captive Water Storage for Fire Fighting.	N/A		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank
	Overhead Tank capacity
15	Exit Signage.	N/A		
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication in lift car Firemen's grounding switch Lift Signage
17	Standby power supply
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> Total area Location
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Batter backup Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh
9.7.12

Signature of the Inspecting Officer
Name Suresh Singh
Designation ADO

Do/Estt

Submitted for approval please.

CFO
[Signature]

[Signature]
10/7/12