

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI**


No. F6/MS/DFS/GH/2012/ 2670

Dated: 23/07/12

**FIRE SAFETY CERTIFICATE**

Certified that the Venus Dx., Guest House, 3423, Hari Mandir Marg, Pahar Ganj, New Delhi-110055 comprised of ground floor (02 guest rooms + reception + Shops ), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (04 guest rooms at each floor), 4<sup>th</sup> floor (02 Guest rooms + Store) total 16 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/1573 dated 01-06-2009. The premises was re-inspected by the officer concerned of this department on 09-07-2012 in the presence of Sh..Ramesh Chand Bharija (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 16 guest rooms with effect from 23/07/2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 23/07/12 at New Delhi by.

  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049.
2. M/s Venus Dx. Guest House, 3423, Hari Mandir Marg, Pahar Gang, New Delhi-110055.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

**INSPECTION REPORT**

*Venus IX, Guest House, 3423,  
Hosi Mandir Marg, Pahar Ganj  
New Delhi-110055*

1. Name & address of the building : \_\_\_\_\_
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOG : Letter No. FG/DES/M-5/64/2009/573 Dated: 01-06-09
5. Fire Safety directives letter No : NIL
6. Date of inspection : 09-07-2012
7. Name of the Inspecting Officers : Dharmvir Singh Yadav.
8. Name and designation of officers from the building side : Shri Ramesh Chand Bhatija (owner)
9. Year of Construction : - N.A -
10. Applicant's letter No. : 41599/ADD-C.P./Lic (H) dated N.D. 11th 28-06-12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	• Gate width	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	• Width of internal road	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	<u>—</u>	<u>one</u>	<u>M.R</u>
	• Basements	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	b. Width of staircases			
	• Upper Floors	<u>—</u>	<u>118 cms to 121 cms</u>	<u>M.R</u>
	• Basements	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	c. Protection of exits			
	• Fire check door	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	• Pressurization	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	e. No. of continuous staircases to terrace	<u>—</u>	<u>one</u>	<u>M.R</u>
	g. Width of Corridor	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>
	h. Door Size	<u>N.A</u>	<u>N.A</u>	<u>N.A</u>

*confd.:-*



Venus Dlx. Guest House, 3423,  
 Hali Mandir Marg, Pahar Gans,  
 New Delhi-110055.

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N.A		
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N.A natural ventilation	N.A M.R
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	— — ISI marked	10 (Ten) ABC & CO <sub>2</sub> Type yes	M.R M.R M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	one 30 m 5 mm	one yes yes	M.R M.R M.R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		N.A	
8	<b>MOEFA</b>	N.A	N.A	N.A
9	<b>Public Address System.</b>	yes	Provided	M.R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N.A	N.A	N.A cost:-

Venas DX, 3423, Gali Hali Mandi,  
Pahar Ganj, New Delhi-11055

	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>			
			N.A	
			225 LPM	M.R
		30 mts	30 mts	M.R
		Electric	Electric	M.R
			Starting switch	
			Provided at G. floor.	M.R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A

Contd:-



Venus DX Guest House,  
3423, Gali Holi Mandir,  
Pahar Ganj, New Delhi - 110055

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
15	Exit Signage.	Yes	Provided	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby		N.A	
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply	—	Provided D.G Set	M.R
18	Refuge Area.			
	➤ Total Area	—	N.A	—
	➤ Location	—	N.A	—
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel		N.A	
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:		N.A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue ~~shortcomings~~ as noted at serial numbers.....

contd:-

Venus DX Guest House  
3423, Gali Hosi Mandi,  
Pahar Ganj, New Delhi-110055.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name Dharmvir Singh Yadav

Designation Assistant Divisional  
Officer (Central)