

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/ *School / 2012 / 2719*

Dated: *25/07/12*

**FIRE SAFETY CERTIFICATE**

Certified that **M.R. Jain Public School, H-16/215, Sangam Vihar, New Delhi**, comprised of lower ground, ground plus one upper floor, was granted NOC by this department vide letter No.F6/DFS/MS/2006/3207 DT 30/10/2006. The school building was re-inspected by officer concerned of Delhi Fire Service on 13.07.2012 in the presence of Mr. Sandeep Jain, Manager of the school and observed that fire safety norms as required under Directorate of Education Circular No.F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 are deemed complied and that the building / premises is fit for occupancy class-B "Educational building" with effect from *25/07/12* for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on *25/07/12* at New Delhi by

*[Signature]*  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

**Copy To -**

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. Manager, M.R. Jain Public School, H-16/215, Sangam Vihar, New Delhi-110062

**Conditions for the validity of fire safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name and address of the building : M.R. JAIN PUBLIC SCHOOL  
 : H-16/215, SANGAM VIHAR,  
 : NEW DELHI - 110062
2. Type of Occupancy : EDUCATIONAL
3. Type of Case : RENEWAL
4. Details of previous NOC : FG/DFS/MS/2006/3207 Dt. 30/10/2006
5. Fire Safety Directives letter No : N/A
6. Date of Inspection : 13.07.2012
7. Name of the Inspecting Officer : RAJAN WADEHRA, ADO/M.Rd.
8. Name and designation of the Officers from the building side : Mr. SANDEEP JAIN, MANAGER
9. Year of Construction : N/A. G+1 floors -
10. Applicant's letter No. : MRJ/12-13/11 dt 05/06/12

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	Old NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Required	Provided	M/R
	• Gate width	Required	Provided	M/R
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	• Number of Staircase			
	➤ Upper floors	TWO	TWO	M/R
	➤ Basement	NA	NA	NA
	• Width of Staircase			
	➤ Upper floors	Old Case	1.45 mts	M/R
	➤ Basement	NA	1.40 mts	NA
	• Protection of Exits		NA	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Width	1.0 Mts	1.0 Mts	M/R

<b>3</b>	<b>Compartmentation</b>	NA		
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>			
<b>4</b>	<b>Smoke Management System</b>	NA		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floors</li> </ul>	30 a/c Per hour		
		12 a/c Per hour		
<b>5</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total Number</li> <li>• Types</li> <li>• IS marking</li> </ul>	<u>One</u> /300 m <sup>2</sup> ABC / CO2 ISI mark	7 Nos Provided YES	MIR MIR MIR
<b>6</b>	<b>First-Aid Hose Reels</b>	NA		
	<ul style="list-style-type: none"> <li>• Total Number on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	___ /Per Floor 30 m 5mm	Provided Provided Provided	MIR MIR MIR
<b>7</b>	<b>Automatic Fire Detection and Alarming System</b>	NA		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>			
<b>8</b>	<b>MOEFA</b>	Required	Provided	MIR
<b>9</b>	<b>Public Address System</b>	NA		
<b>10</b>	<b>Automatic Sprinkler System</b>	NA		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
<b>11</b>	<b>Internal Hydrant</b>	NA		
	<ul style="list-style-type: none"> <li>• Size of riser/down comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	Not-Reqd. Not-Reqd. Not-Reqd.	Provided One Provided	MIR MIR MIR
<b>12</b>	<b>Yard Hydrant</b>	NA		
	<ul style="list-style-type: none"> <li>• Total Number of hydrants</li> <li>• Hose Box</li> </ul>			

<b>13</b>	<b>Pumping Arrangements</b>				
	Ground Level				NA
	➤ Number of main pump				
	➤ Discharge of main pump				
	➤ Head of main pump				
	➤ Jockey pump out put				
	➤ Jockey pump Head				
	➤ Standby pump out put				
	➤ Standby Pump Head				
	➤ Auto Starting/Manual stopping				
	➤ Pump House Access				
	Terrace level				NA
	➤ Discharge of pump				
	➤ Head of the pump				
	➤ Power Supply				
	➤ Auto starting /Manual stopping				
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>				NA
	• Underground tank capacity				
	➤ Draw-off connection				
	➤ Fire service inlet				
	➤ Access to tank				
	• Overhead tank capacity				
<b>15</b>	<b>Exit Signage</b>				NA
<b>16</b>	<b>Provision of Lifts</b>				NA
	• Pressurization of Lift Shaft				
	• Pressurization of Lift lobby				
	• Communication in lift Car				
	• Fireman's Grounding Switch				
	• Lift Signage				
<b>17</b>	<b>Standby Power Supply</b>				NA
<b>18</b>	<b>Refuge Area</b>				NA
	• Total Area				
	• Location				
<b>19</b>	<b>Fire Control Room</b>				NA
	• Detector System Panel				
	• Flow Switch Panel				
	• PA System Panel				
	• Battery back up				
	• Building Floor Plans				

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number.....~~.....

**Signature of Inspecting Officer**

Name :

Designation:

Do (South)

  
18/7/12

**Signature of Inspecting Officer**

Name : RAJAN WADEHRA

Designation: A. D. O. (M.Rd.)

