

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 2774

Dated: 27/07/12

FIRE SAFETY CERTIFICATE

Certified that M/s **Delhi Guest House located at 934, Bazar Matia Mahal, Jama Masjid, Delhi** comprised of ground floor (Commercial use), first floor (03 guest rooms + 01 dormitory + reception) & second floor (05 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/1485 dated 17-02-2009. The premises was re-inspected by the officer concerned of this department on 18-06-2012 in the presence of Mohd. Sulaiman, Partner of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 27/07/12 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 27/07/12 at New Delhi by.


Chief Fire Officer
Director
Delhi fire service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Owner, M/s Delhi Guest House, 934, Bazar Matia Mahal, Jama Masjid, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

Old Case

INSPECTION REPORT

1. Name & address of the building : Delhi Guest House, 934, Bazar Malia Mahal
2. Type of Occupancy : Lodging House / Eating House / Club Jama Masjid, Delhi.
3. Type of Case : Renewal / New case
4. Details of previous NOC : Letter No. FE/DF/MS/GH/2009/1485 Dated: 17/2/2009
5. Fire Safety directives letter No : —
6. Date of inspection : 18/6/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Mohd. Sulaiman, Manager/partner
9. Year of Construction : prior to 1947
10. Applicant's letter No. : 41318/ Addl. CP/4c(H) dated 27/2/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	—	12 mt	MR
	• Gate width	—	Directly accessible from the road	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	—
	b. Width of staircases	—	—	—
	• Upper Floors	0.80 mt	0.83 mt	MR
	• Basements	N/A	N/A	—
	c. Protection of exits	N/A	N/A	—
	• Fire check door	N/A	N/A	—
	• Pressurization	N/A	N/A	—
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	—
	h. Door Size	N/A	N/A	—
		—	—	—
3	Compartmentation.	Not required	—	—

CF - Commercial
 1st floor - 03 guest rooms + 01 dormitory + reception
 2nd floor - 05 guest rooms

Delhi Guest House, 934, Bazar main Mahal
Jama Masjid, Delhi

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	-
		NA	NA	-
		NA	NA	-
		NA	NA	-
		NA	NA	-
4	Smoke Management System.	Not required		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	-
		12 a/c per hour	NA	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Water CO ₂ - 3	provided	MR
		CO ₂ - 3	provided	MR
		ISI marked	provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	_____	NA	-
		30 m	NA	-
		5 mm	NA	-
7	Automatic fire detection and alarming system.	Not required		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	-
		NA	NA	-
		NA	NA	-
		NA	NA	-
		NA	NA	-
8	MOEFA	NA	NA	-
9	Public Address System.	NA	NA	-
10	Automatic Sprinkler System.	Not required		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	-
		NA	NA	-
		NA	NA	-
11	Internal Hydrants	Not required		
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	-

4

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	N/A	N/A	—
		N/A	N/A	—
12	Yard Hydrants. Not required			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	—
		N/A	N/A	—
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
		N/A	N/A	—
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. Not applicable			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	—


(Signature)

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
17	Standby power supply	Required	8 VA	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-
	➤ Location	N/A	N/A	-
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-
	• Flow Switch Panel	N/A	N/A	-
	• PA System Panel	N/A	N/A	-
	• Batter backup	N/A	N/A	-
	• Building Floor Plans	N/A	N/A	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher found provided near E panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~grant~~ / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation


Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer