

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2012/2799

Dated: 27 / 07 / 2012

FIRE SAFETY CERTIFICATE

Certified that the **Kamal Pharmacy (Ayurvedic) pvt. Ltd** located at 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015., comprised of ground floor magazine and first floor was granted NOC by this department vide letter F-5/(3)/DFS/MS/2007/80 dated 31-01-2009. The premises was re-inspected by the officers concerned of this department on **18/07/2009** in the presence of **Mr. Kamal Arora (Director)** of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-G (G-1) Industrial** occupancy with effect from 27/07/12 for a period of three years subject to conditions printed over leaf.

Issued on 27/07/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

022

Copy to:
Mr. Kamal Arora (Director)
Kamal Pharmacy (Ayurvedic) pvt. Ltd
14, Industrial Area, Shivaji Marg, (Najafgarh Road),
New Delhi-110015

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. KPPL/35/12 dated 26-04-12 received from the Director for Kamal Pharmacy (Ayurvedic) pvt. Ltd., regarding of NOC in r/o **Kamal Pharmacy (Ayurvedic) pvt. Ltd** located at 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015. Premises was inspected & observed that the building comprised of ground floor, Mazz. floor & first floor only. Fire safety arrangements are put up on the prescribed Performa :-

1. Name & address of the building : **Kamal Pharmacy (Ayurvedic) pvt. Ltd** located at 14, Industrial Area, Shivaji Marg, (Najafgarh Road), New Delhi-110015.
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F-5/(3)/DFS/MS/2007/373 dated 18-09-2007
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 18-07-2012
7. Name of the Inspecting Officers : Division Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Kamal Arora (Director)
9. Year of Construction :
10. Applicant's letter No. : KPPL/35/12 dated 26-04-12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Old case	Provided 12 mtr width	M.R.
	• Gate width	4.5 mtr	Provided 5 mtr width	M.R.
	• Width of internal road	N.R.	N.R.	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	1	Provided	M.R.
	• Upper Floors	NR	NR	M.R.

	<ul style="list-style-type: none"> Basement 	N.A	N.A	N.A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basement 	Old case	Provided 1 mtr width	M.R.
		N.A	N.A	N.A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N.R	N.R	N.R
		N.R	N.R	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Halls only	Halls only	M.R.
	f. Door size	Old case	1 mtr	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N.R	N.R	N.R.
		N.R	N.R	N.R.
		N.R	N.R	N.R.
		N.R	N.R	N.R.
		N.R	N.R	N.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	N.A	N.A	N.A
		required	Exhaust fans are provided	M.R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types 	10 ABC type	13 provided	M.R M.R

	<ul style="list-style-type: none"> ISI marking 	ISI marked required	provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	Provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.R	N.R	N.A
	<ul style="list-style-type: none"> Location of Main Panel 	N.R	N.R	N.A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.R	N.R	N.A
	<ul style="list-style-type: none"> Alternate source of power 	N.R	N.R	N.A
	<ul style="list-style-type: none"> Hooter's Location 	N.R	N.R	N.A
8.	MOEFA	N.R	Provided	M.R.
9.	Public Address System.	N.R.	N.R.	N.A
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Upper Floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N.R.	N.R.	N.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	M.R.

	• Hose Box	1	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	Not applicable.
	• Hose Box	N.R.	N.R.	Not applicable
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R
	➤ Head of Main pump	N.R.	N.R.	N.R
	➤ Number of main pumps	N.R.	N.R.	N.R
	➤ Jockey Pump out put	N.R.	N.R.	N.R
	➤ Jockey pump head	N.R.	N.R.	N.R
	➤ Standby pump out put	N.R.	N.R.	N.R
	➤ Standby pump Head	N.R.	N.R.	N.R
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R
	➤ Pump Hose Access	N.R.	N.R.	N.R
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R
	➤ Head of the pump	40 mtr	provided	M.R
	➤ Power supply	Required	provided	M.R
	➤ Auto Starting of pump	Manual	Provided	M.R

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.R.	N.R.	N.R. ✓
	➤ Draw -off connection	N.R.	N.R.	N.R. ✓
	➤ Fire service inlet	N.R.	N.R.	N.R. ✓
	➤ Access to tank	N.R.	N.R.	N.R. ✓
	➤ Overhead Tank Capacity	10,000 ltr	12,000 ltr provided	M.R. ✓
15	Exit Signage.	N.R.	N.R.	N.A.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A. ✓	N.R. ✓	N.R. ✓
	• Pressurization of Lift lobby	N.A. ✓	N.R. ✓	N.R. ✓
	• Communication In lift Car	N.A. ✓	N.R. ✓	N.R. ✓
	• Fireman's Grounding Switch	N.A. ✓	N.R. ✓	N.R. ✓
	• Lift Signage	N.A. ✓	N.R. ✓	N.R. ✓
17.	Standby power supply	Required ✓	Provided ✓	M.R. ✓
18.	Refuge Area	N.R.	N.R.	N.A. ✓
	➤ Total Area	N.R. ✓	N.R. ✓	N.A. ✓
	➤ Location	N.R. ✓	N.R. ✓	N.A. ✓
19.	Fire Control Room			
	➤ Detector System Panel	N.R. ✓	N.R. ✓	Not applicable ✓
	➤ Flow Switch Panel	N.R. ✓	N.R. ✓	Not applicable ✓
	➤ PA system Panel	N.R. ✓	N.R. ✓	Not applicable. ✓

	➤ Batter backup	N.R.	N.R.	Not applicable.
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chawdhary

Name

Designation

D.O. (West)

Designation